

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 07, 2025 Inspection Result: PASSED

Permit Number: PRCTI20250537

Property Address: 302 33RD ST SE, PUYALLUP, WA 98372;

Contractor: DELANEY CONSTRUCTION LLC 635 TRADE CTR CHESTERFIELD, MO

63005

To construct: OFFICE TI; SCOPE TO INCLUDE BUILDING & MECH; EXISTING LARGE

OFFICE SPACE- TO BE CONVERTED TO SEVERAL SMALL OFFICES; FULL HEIGHT PARTITIONS; CREATE ADDITIONAL OFFICE & STORAGE SPACE;

REVISED ALL LIGHTING BUILD/MECH COMBINED

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. Debris on top of ceiling grid.
 - 2. Electrical bracing and open electrical box not attached to ceiling grid.
 - 3. Duct registers must be attached to T-bar main run as well as opposite side.
 - 4. New heat duct must be insulated.
 - 5. Spreader bars and burk clips must be installed.
 - 6. Provide at least three turns of support wire for light fixtures.

Sincerely,

James LaVergne JLaVergne@PuyallupWA.gov (253) 841-5590