



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 10, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20240808

Property Address: 911 SHAW RD, PUYALLUP, WA 98372; 901 SHAW RD, PUYALLUP, WA 98372; 813 SHAW RD, PUYALLUP, WA 98372;

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Phase 2 site development of East Town Crossing including grading, storm drainage, parking, and utilities per plans. - 731 SHAW RD

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: See corrections.

Corrections:

- 1 1. Please maintain silt fence where areas have fallen or toe uncovered.
2. Please add straw to bare areas that not being worked.
3. Please clean (empty) ALL silt socks.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387