



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 11, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20250372

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 773-3360

To construct: SITE WORK ASSOCIATED W/COP PUBLIC SAFETY BDLG

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Contractor air tested storm @ 3psi for 15min.

- SD3 to SD4 106LF of 12"pvc (PASSED)
- SD3 to SD1 118LF of 12"pvc (PASSED)

Corrections:

Sincerely,

Jason Little
Development Engineering Inspector



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

JLittle@PuyallupWA.gov

(253) 244-0387