



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 13, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20240275

Property Address: 1023 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: Installation of foundations and steel supports for exterior chiller piping and electrical conduit, as well as installation of fluid coolers, air cooled chillers, pumps and miscellaneous mechanical equipment - CENTERIS VOLTAGE PARK - REVISION (1) MECHANICAL PLAN REVIEW TO INCLUDE COMPLETE MECHANICAL SET (THIS WILL REPLACE WHAT WAS ORIGINALLY STAMPED MECH PLANS) * REVISION (2) - 10/30/2024 - ADD TRANSFER FAN BETWEEN UPS ROOM & BATTERY ROOM * REVISION (3) - 10/17/2025 - MECHANICAL CHANGES

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590