



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 13, 2025

Inspection Result: **FAILED**

Permit Number: PRCNC20241917

Property Address:

Contractor: E M PRECISION LLC 1407 VALENTINE AVE SE, STE 105 PACIFIC, WA 98047 (253) 268-0742

To construct: Ground up construction of a McDonald's with a Drive Through. -
MCDONALD'S - EAST TOWN CROSSING - 731 SHAW RD

On this day we have inspected your construction for **Light Test For Grease Duct Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Several pin hole locations in all three duct works. Call for reinspection.

Corrections:

1 1. Several pin hole locations in all three duct works. Call for reinspection.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590