



City of Puyallup
Building Division
333 S Meridian
Puyallup, WA 98371

November 17th, 2025

Permit Application # PRPO20251253

Dear Building Division,

Here are our responses for the Wesley Bradley Pool and Spa construction permit.

- 1) Attached new plan set with engineer stamp.
- 2) Yes the provided GEO Report applies to this project as well.
- 3) Correct, the spa has a maximum temperature of 104 degrees (F). The pool heaters have safety switches that will not allow them to heat over 104 degrees. Make up water for this pool and spa will be cold water. Make up water is the fill water attached to the automatic fill systems.
- 4) The WAC code, which we use in Washington States no longer than 15 minutes for the spa jets. I am not sure where the 10 minute timer came from. The Tacoma Pierce County Health Department WAC: 246-260-131(5)(iv)

(iv) Cautioning everyone to limit the stay in the spa pool to fifteen minutes at any one session;

Also, Washington State is about to adopt the Model Aquatic Health Code and that states:
4.12.1.10A Timers The Hydrotherapy jet system shall be connected to a minute timer that does not exceed 15 minutes to limit the period of agitation.

- 5) The spa heater will not allow water warmer than 104 degrees (F).
- 6) The Spa turnover rate has been fixed on the plans to say minutes. The turnover rate for the spa is 18.86 Minutes.

Thank you,

Ben Egeland

Ben Egeland
Orca Pacific Inc.
280 44th Street NW
Auburn, WA 98001