



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 21, 2025 **Inspection Result:** **PASSED**

Permit Number: PRCTI20251325

Property Address: 1007 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: HOWARD S. WRIGHT CONSTRUCTION CO. 415 1ST AVE #400 N
SEATTLE, WA 98109

To construct: KAISER PUYALLUP MEDICAL CENTER EXISTING X-RAY IMAGING SUITE
EQUIPMENT REPLACEMENT. NEW UPGRADE WILL INCLUDE
REPLACEMENT OF THE PREVIOUS PHILIPS X-RAY WITH NEW SIEMENS
IMAGING EQUIPMENT AND FINISHES UPGRADE. NEW WORK TO
INCLUDE PARTIAL DEMOLITION OF CONTROL ROOM WALL TO
RETROFIT SPACE WITH NEW 90 DEGREE PARTIAL HEIGHT WALL.

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. Screw burke clips in ceiling grid assembly.
2. Patch and seal sheetrock penetrations.
3. Replace or repair broken or cut ceiling grid wire.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590