



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Nov 21, 2025

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20250324

**Property Address:** 1015 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 773-3360

**To construct:** Commercial tenant improvement to existing 50,767 sf space - COP ~  
PUBLIC SAFETY BUILDING \* REVISION (1) - 8/21/2025 - GENERATOR  
DEFERRED SUBMITTAL \* REVISION (2) - 10/30/2025 - EXTERIOR  
CANOPY CONNECTIONS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. Provide UL listing from engineer on 2hr fire wall. Have detail printed on site at time of inspection.

**Corrections:**

1. Provide UL listing from engineer on 2hr fire wall. Have detail printed on site at time of inspection.

Sincerely,

James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590