



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 24, 2025

Inspection Result: **FAILED**

Permit Number: PRCTI20241512

Property Address: 1201 39TH AVE SW, PUYALLUP, WA 98373;

Contractor: PACIFIC NORTHERN ENVIRO CORP 1081 COLUMBIA BLVD LONGVIEW, WA 98632-1024

To construct: INSTALLATION OF NEW INTERIOR PARTITIONS, PLUMBING FIXTURES, RESTROOM ACCESSORIES, FINISHES, CEILING AND LIGHTING, RESTROOMS ARE TO MEET LOCAL REQUIREMENTS.~ COSTCO FLEET RESTROOM REMODEL

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Provide full legible city approved plans on site at time of inspection.
2. Provide fire final at time of building final.
3. Provide fire strobe/smoke detector for new bathroom.
4. provide electrical final at time of building final inspection.

Corrections:

- 1 1. Provide full legible city approved plans on site at time of inspection.
2. Provide fire final at time of building final.
3. Provide fire strobe/smoke detector for new bathroom.
4. provide electrical final at time of building final inspection.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org