



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 24, 2025 **Inspection Result:** **FAILED**

Permit Number: PRCTI20250558

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: SELLEN CONSTRUCTION CO INC PO BOX 9970 SEATTLE, WA 98109-9970 ABBOTT CONSTRUCTION 3408 1ST AVENUE SOUTH SEATTLE, WA 98134

To construct: Phase 0 will create new storage capacity and access points for hospital staff prior to the full buildout of the expanded Kitchen. MULTICARE GOOD SAMARITAN HOSPITAL KITCHEN PHASE 0

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Provide approved UL listing for fire wall.
2. Provide electrical final at time of frame inspection.
3. Remove sheetrock screws in upper deflection track.
4. Okay to one side sheetrock.

Corrections:

- 1 1. Provide approved UL listing for fire wall.
2. Provide electrical final at time of frame inspection.
3. Remove sheetrock screws in upper deflection track.
4. Okay to one side sheetrock.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org