



12181 C Street South Tacoma, WA 98444
Ph : 253-274-5701

City of Puyallup
Building Division
333 S. Meridian
Puyallup, WA 98371
Public Works and Utilities

24 November 2025

Subject: Permit Application PRMH20251486
Reddot Test Booth Air Conditioning

Puyallup Permit Center:

In response to your letter dtd November 13, 2025, we are providing the following additional information and responses.

- Energy Code Worksheets
We are providing the Washington State Energy Code Worksheets for Mechanical systems
- Floor Plan
The Key plan on drawing M-101 shows the building and the area of the project.
- Structural Calculations for Mechanical Permit
Per my discussion with Stan Kinnear in the Puyallup Building Division, no structural calculations are required per ASCE 7 (unit is less than 400lbs)
- Structural Plans for Mechanical Permit
Per my discussion with Stan Kinnear in the Puyallup Building Division, no structural drawings are required per ASCE 7 (unit is less than 400lbs)

Please call if I can be of any assistance.

A handwritten signature in blue ink, appearing to read "Ted A. Veach".

Ted A. Veach P.E.
Principal