



City of Puyallup
Engineering Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

November 25, 2025

Brett Lindsay
523 N D St
Tacoma, WA 98403
blindsay@synthesis9.com

**RE: Alternative Methods /Materials Request (AMR) for Permit PRAMR20251508
East Town Crossing - Lot 1**

Dear Brett Lindsay,

The City reviewed the Alternative Methods/Materials Request described by the permit applicant as, "This project is seeking deviation from the 3 ft clearance requirement for the Post Indicator Valve (PIV) serving Lot 1 of the development. - 3002 E PIONEER". The request is **Approved** with the following conditions:

Conditions
1. The conditional approval is based on the site plan and that the valve handle will have vertical clearance above the guardrail for the full turning circumference.

The signed AMR application is available to view and download in the CityView portal. If you have any questions regarding this decision, or would like to further discuss your request, please contact me directly.

Sincerely,

(253) 841-5559
MHigginson@PuyallupWA.gov