



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 26, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20241846

Property Address: 731 SHAW RD, PUYALLUP, WA 98372

Contractor: EM Precision, LLC 1407 Valentine Ave SE, Suite 105 Pacific, WA 98047--
2104

To construct: Ground up commercial fast food restaurant with a drive through. -
MCDONALD'S - EAST TOWN CROSSING - 731 SHAW RD

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The entire fire line and the north hydrant were pressure tested @ 200psi for 2hrs w/zero pressure drop. (PASSED)

Note: Fire inspection card has been updated.

Corrections:

Sincerely,

Jason Little



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387