



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 02, 2025

Inspection Result:

**PASSED W/
CONDITIONS**

Permit Number: PRCNC20251159

Property Address: 3002 E PIONEER, PUYALLUP WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: COVERED, NON-COMBUSTIBLE STRUCTURE FOR STORAGE OF TRASH
AND RECYCLE. * EAST TOWN CROSSING - NORTH TRASH CLOSURE -
3002 E PIONEER

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 1. Turn anchor bolts to correct orientation.
2. Wrap, plumbing, water supply in footing stem wall.
3. Install additional transverse bars under horizontal or provide Engineering approval.
4. Have full set of city approved plans on site at time of inspections.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590