



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Dec 03, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20250697

**Property Address:** 310 31ST AVE SE, PUYALLUP, WA 98374;

**Contractor:** E M PRECISION LLC 1407 VALENTINE AVE SE, STE 105 PACIFIC, WA 98047 (253) 268-0742

**To construct:** INTERIOR ALTERATION: CONVERT VACANT RESTAURANT SPACE TO WIENERSCHNITZEL RESTAURANT. MINOR WALL CHANGES AND NEW CEILING. PROVIDE NEW KITCHEN EQUIPMENT, FIXTURES, FINISHES AND DINING FURNITURE. NO CHANGES TO BUILDING ENVELOPE. - WIENERSCHNITZEL SOUTH HILL

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Remove screws from new framed walls in ceiling grid and provide kicker braces to structure. Okay to one side sheetrock.

**Corrections:**

Sincerely,

James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590