



City of Puyallup
Building Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 04, 2025

Inspection Result: **FAILED**

Permit Number: PRCNC20241019

Property Address: 3303 8TH AVE SE, Unit: E, PUYALLUP, WA 98372;

Contractor: MOUNTAIN CONSTRUCTION 3411 90TH ST S; SUITE A LAKEWOOD, WA 98499 (253) 474-5281

To construct: Construct Early Learning Center

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

1. Screw off registers to main runs of T-bar grid not cross members.
2. Screw off burke clips at perimeter of grid.
3. Finish condensates above ceiling grid.
4. Provide smoke alarm in ceiling grid.

Corrections:

1. Screw off registers to main runs of T-bar grid not cross members.
2. Screw off burke clips at perimeter of grid.
3. Finish condensates above ceiling grid.
4. Provide smoke alarm in ceiling grid.

Sincerely,

James LaVergne
JLaVergne@PuyallupWA.gov
(253) 841-5590