



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Dec 04, 2025                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20241846

**Property Address:** 731 SHAW RD, PUYALLUP, WA 98372

**Contractor:** EM Precision, LLC 1407 Valentine Ave SE, Suite 105 Pacific, WA 98047--  
2104

**To construct:** Ground up commercial fast food restaurant with a drive through. -  
MCDONALD'S - EAST TOWN CROSSING - 731 SHAW RD

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** SSS flushed the south hydrant from 1-2.5 hose for 15min. (PASSED)

The entire fire line was flushed. Single (swing) check diaphragm was removed for testing and flush. 2-2.5" hoses from floor flange and 2-2.5" hoses from FDC were flushed twice for 15min each time. (PASSED)

Note: Discussed sewer testing and dumpster pad sewer connection install. Sewer needs to be air tested, TV, and mandrel pulled. Dumpster pad SS needs the existing CB removed and tied on to existing SS stub with c/o's.

**Corrections:**

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 244-0387