



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Dec 05, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRCTI20240158

**Property Address:** 324 S MERIDIAN, PUYALLUP, WA 98371;

**Contractor:** SOVA CONSTRUCTION LLC 21924 22ND AVE E SPANAWAY, WA 98387  
(253) 820-5708

**To construct:** Library tenant improvement of "Teen Zone" on Level 2. Remodel of existing teen lounge to include new shelving wall, new lighting, new study cubbies, and new study room. - LIBRARY TEEN ZONE

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. Provide interior unlocking door hardware at rotary study room.  
2. Have fire final inspection done before building final.  
3. Have approved full size city prints on site at time of inspection.

**Corrections:**

- 1 1. Provide interior unlocking door hardware at rotary study room.
2. Have fire final inspection done before building final.
3. Have approved full size city prints on site at time of inspection.

Sincerely,

James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590