

**SMITH FIRE SYSTEMS, INC**

1106 54TH AVENUE EAST TACOMA, WASHINGTON 98424

(253) 926-1880 Fax (253) 926-2350

CONTR. REG. NO. SMITHFS1360T

**GENERAL / HYDRAULIC CALCULATION INFORMATION SHEET**

PROJECT NAME:	BRADLEY HEIGHTS	JOB NO.:	TC25207	OWNER:	
	BUILDING H	DATE:	11/6/2025	CRP/TP BRADLEY HEIGHTS LLC	
ADDRESS:	206 27TH AVE SE	BY:	A. RIDEOUT	AHJ:	
	PUYALLUP, WA 98374			PUYALLUP	

SYSTEM DESIGNATION: **SYSTEM #1 -L3 (4) HEAD COMPARTMENT**DESIGN PER: **NFPA 13R (2019 EDITION)**OCCUPANCY CLASSIFICATION: **RESIDENTIAL****DESIGN CRITERIA:**NFPA SECTION: **7.2.3**
AREA MODIFIER **N/A**SPRINKLER MANUFACTURER: **RELIABLE**
K-FACTOR: **4.9K**
MODEL: **F1RES49**
TEMPERATURE: **155°**
RESPONSE TYPE: **QR**SYSTEM TYPE: **WET**
MAX CEILING HEIGHT: **9'-1"**
CEILING HEIGHT: **9'-1"**
ROOF SLOPE: **4:12**
CEILING SLOPE: **2:12**TOTAL SPRINKLERS CALCULATED: **4**
MAX AREA OF COVERAGE PER SPRINKLER: **256 SQ. FT**
MAX DISTANCE BETWEEN SPRINKLERS: **16 FT**FIRE PUMP: **N**
RATED CAPACITY OF PUMP: **N/A****DESIGN AREA**

THE (4) HYDRAULICALLY MOST DEMANDING ADJACENT SPRINKLERS DELIVERING .05 GPM/SQ. FT. OR PER THE SPRINKLER LISTING, WHICHEVER IS MORE DEMANDING.

ALLOWANCES INCLUDED IN CALCULATIONS:ADDED AT:OUTSIDE HOSE **0 GPM**

CITY CONNECTION

WATER SUPPLY:	ELEVATION OF TEST: 0 FT.	ELEVATION OF LEVEL 1: 0 FT.	MAIN DRAIN TEST:
STATIC 95 PSI	DATE OF TEST: 4/19/2001		S: R:
RESIDUAL 90 PSI	DATA PROVIDED BY: FRUITLAND WATER		INSPECTORS TEST:
FLOW 1055 GPM	LOCATION OF TEST: FH @ 207 27TH AVE SE		TRIP TIME:

WET SYSTEM NUMBER 1

AREA	SQ. FT.	SPRINKLERS
FLOOR 1	8400	85
FLOOR 2	8040	80
FLOOR 3	8296	90

TOTAL: 24,736 255

MOST DEMANDING AREA: SYS. 1

MOST DEMANDING (4) SPRINKLER(S) AT 7 PSI

BASE OF RISER: 64 GPM REQUIRED AT 54.1 PSI**SUMMARY:** 64 GPM REQUIRED AT 66.7 PSIAT CONNECTION TO **SOURCE**(INCLUDING **0 GPM** FOR HOSE STREAMS)**NOTES:**



SMITH FIRE SYSTEMS, INC.

WATER SUPPLY DATA

STATIC 90 PSI
RESIDUAL 95 PSI
FLOWING 1055 GPM

JOB NAME BRADLEY HEIGHTS APARTMENTS

ADDRESS 206 27TH AVE SE, BLDG H

DATE PUYALLUP, WA 98374

JOB NO. TC25207

SYSTEM/AREA SYS 1: (4) 16x16 RES49


MOST DEMANDING AREA: SYS. 1

MOST DEMANDING (4) SPRINKLER(S) AT 7 PSI

BASE OF RISER: 64 GPM REQUIRED AT 54.1 PSI

SUMMARY: 64 GPM REQUIRED AT 66.7 PSI

AT CONNECTION TO SOURCE
(INCLUDING 0 GPM FOR HOSE STREAMS)



DATE: 11/6/2025RAULICS\HASS FILES\BUILDING H\H - (4) 16X16 RES49 7PSI.SDF

JOB TITLE: H - (4) 16x16 RES49 7PSI

WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (PSI)	RESID. PRESS. (PSI)	FLOW @ (GPM)	AVAIL. PRESS. (PSI)	TOTAL @ DEMAND (GPM)	REQ'D PRESS. (PSI)
SOURCE	95.0	90.0	1055.0	95.0	64.0	66.7

Available pressure is 28.3 psi (30%) greater than required pressure.

AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	64.0 GPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	0.0 GPM
OTHER HOSE STREAM ALLOWANCES	0.0 GPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	64.0 GPM

NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)
S2	30.3	K= 4.90	7.8	13.7
S3	31.9	K= 4.90	7.0	13.0
S4	29.3	K= 4.90	14.9	18.9
S5	32.4	K= 4.90	14.2	18.5
B1	29.8	- - - -	8.5	- - -
B2	29.8	- - - -	16.0	- - -
M2	29.8	- - - -	16.1	- - -
M3	29.8	- - - -	16.8	- - -
31	29.7	- - - -	16.9	- - -
01	9.5	- - - -	31.0	- - -
TOR	14.5	- - - -	50.9	- - -
BFP1	7.6	- - - -	54.1	- - -
BFP2	7.6	- - - -	61.1	- - -
UG1	0.0	- - - -	38.7	- - -
UG2	0.0	- - - -	40.0	- - -
UG3	2.5	- - - -	45.7	- - -
UG4	2.5	- - - -	47.3	- - -
UG7	5.0	- - - -	62.3	- - -
UG8	5.0	- - - -	62.3	- - -
UG9	-5.2	- - - -	66.7	- - -
SOURCE	-5.2	SOURCE	66.7	64.0

DATE: 11/6/2025RAULICS\HASS FILES\BUILDING H\H - (4) 16X16 RES49 7PSI.SDF
JOB TITLE: H - (4) 16x16 RES49 7PSI

PIPE DATA

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.	
NODES		(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	(FT)	SUM.	
							FL/FT		(PSI)	
Pipe: 1										
S2		30.3	4.9	7.8	13.7	-13.7 4.6	1.101 PL	2.75	PF	0.4
B1		29.8	0.0	8.5	0.0		150 FTG	2T	PE	0.3
							0.034 TL	12.75	PV	
Pipe: 2										
S3		31.9	4.9	7.0	13.0	-13.0 4.4	1.101 PL	6.75	PF	0.5
B1		29.8	0.0	8.5	0.0		150 FTG	ET	PE	0.9
							0.030 TL	16.75	PV	
Pipe: 3										
S4		29.3	4.9	14.9	18.9	-18.9 6.4	1.101 PL	11.67	PF	1.3
B2		29.8	0.0	16.0	0.0		150 FTG	ET	PE	-0.2
							0.061 TL	21.67	PV	
Pipe: 4										
B1		29.8	0.0	8.5	0.0	-26.6 9.0	1.101 PL	31.17	PF	7.6
M2		29.8	0.0	16.1	0.0		150 FTG	6ET	PE	0.0
							0.115 TL	66.17	PV	
Pipe: 5										
B2		29.8	0.0	16.0	0.0	-18.9 3.0	1.598 PL	6.00	PF	0.1
M2		29.8	0.0	16.1	0.0		150 FTG	----	PE	0.0
							0.010 TL	6.00	PV	
Pipe: 6										
S5		32.4	4.9	14.2	18.5	-18.5 6.2	1.101 PL	14.42	PF	1.4
M3		29.8	0.0	16.8	0.0		150 FTG	2T	PE	1.2
							0.059 TL	24.42	PV	
Pipe: 7										
M3		29.8	0.0	16.8	0.0	-18.5 3.0	1.598 PL	5.25	PF	0.1
31		29.7	0.0	16.9	0.0		150 FTG	T	PE	0.0
							0.010 TL	13.25	PV	
Pipe: 8										
M2		29.8	0.0	16.1	0.0	-45.5 7.3	1.598 PL	7.75	PF	0.8
31		29.7	0.0	16.9	0.0		150 FTG	T	PE	0.0
							0.051 TL	15.75	PV	
Pipe: 9										
31		29.7	0.0	16.9	0.0	-64.0 10.2	1.598 PL	20.24	PF	5.4
01		9.5	0.0	31.0	0.0		150 FTG	4ET	PE	8.8
							0.095 TL	56.24	PV	
Pipe: 10										
01		9.5	0.0	31.0	0.0	-64.0 10.2	1.598 PL	15.00	PF	3.5
UG1		0.0	0.0	38.7	0.0		150 FTG	2ET	PE	4.1
							0.095 TL	37.00	PV	
Pipe: 11										
UG1		0.0	0.0	38.7	0.0	-64.0 6.5	2.003 PL	25.08	PF	1.4
UG2		0.0	0.0	40.0	0.0		150 FTG	2E	PE	0.0
							0.032 TL	43.08	PV	
Pipe: 12										
UG2		0.0	0.0	40.0	0.0	-64.0 10.2	1.598 PL	55.00	PF	6.8
UG3		2.5	0.0	45.7	0.0		150 FTG	2T	PE	-1.1
							0.095 TL	71.00	PV	
Pipe: 13										
UG3		2.5	0.0	45.7	0.0	-64.0 6.5	2.003 PL	30.33	PF	1.5
UG4		2.5	0.0	47.3	0.0		150 FTG	2E	PE	0.0
							0.032 TL	48.33	PV	

DATE: 11/6/2025RAULICS\HASS FILES\BUILDING H\H - (4) 16X16 RES49 7PSI.SDF
 JOB TITLE: H - (4) 16x16 RES49 7PSI

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.
NODES	(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	FL/FT	(FT)	SUM.
									(PSI)
Pipe: 16					-64.0	1.598	PL	44.00	PF 8.9
UG4	2.5	0.0	47.3	0.0	10.2	150	FTG	7E	PE -5.2
TOR	14.5	0.0	50.9	0.0		0.095	TL	93.00	PV
Pipe: 17					-64.0	2.185	PL	6.92	PF 0.1
TOR	14.5	0.0	50.9	0.0	5.5	150	FTG	----	PE 3.0
BFP1	7.6	0.0	54.1	0.0		0.021	TL	6.92	PV
Pipe: 18									
BFP2	7.6	0.0	61.1	0.0		7.0 psi,		64.0 gpm	FIXED PRESSURE LOSS DEVICE
BFP1	7.6	0.0	54.1	0.0					
Pipe: 19					-64.0	4.100	PL	50.50	PF 0.1
BFP2	7.6	0.0	61.1	0.0	1.6	140	FTG	ET2G	PE 1.1
UG7	5.0	0.0	62.3	0.0		0.001	TL	91.50	PV
Pipe: 20					-64.0	8.270	PL	95.00	PF 0.0
UG7	5.0	0.0	62.3	0.0	0.4	140	FTG	TG	PE 0.0
UG8	5.0	0.0	62.3	0.0		0.000	TL	148.00	PV
Pipe: 21					-64.0	12.340	PL	460.00	PF 0.0
UG8	5.0	0.0	62.3	0.0	0.2	140	FTG	TFG	PE 4.4
UG9	-5.2	0.0	66.7	0.0		0.000	TL	567.00	PV
Pipe: 22					-64.0	6.160	PL	20.00	PF 0.0
UG9	-5.2	0.0	66.7	0.0	0.7	140	FTG	EG	PE 0.0
SOURCE	-5.2	SRCE	66.7	(N/A)		0.000	TL	36.00	PV

NOTES (HASS):

- Calculations were performed by the HASS 2023 D computer program in accordance with NFPA (2020) under license no. 64621553 granted by
 HRS Systems, Inc.
 208 Southside Square
 Petersburg, TN 37144
 (931) 659-9760
- The system has been calculated to provide an average imbalance at each node of 0.003 gpm and a maximum imbalance at any node of 0.067 gpm.
- Total pressure at each node is used in balancing the system. Maximum water velocity is 10.2 ft/sec at pipe 9.
- Items listed in bold print on the cover sheet
 are automatically transferred from the calculation report.
- Available pressure at source node SOURCE under full flow conditions is 94.95 psi with a flow of 83.19 gpm.

DATE: 11/6/2025RAULICS\HASS FILES\BUILDING H\H - (4) 16X16 RES49 7PSI.SDF

JOB TITLE: H - (4) 16x16 RES49 7PSI

(6) PIPE FITTINGS TABLE

User Pipe Table Name: SMITH

PAGE: D	MATERIAL: DI	HWC: 140				
Diameter	Equivalent Fitting Lengths in Feet					
(in)	E	T	F	C	B	G
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv
4.100	8.00	27.00	6.00	30.00	20.00	3.00
6.160	12.00	40.00	10.00	43.00	16.00	4.00
8.270	18.00	47.00	12.00	60.00	20.00	6.00
12.340	24.00	80.00	19.00	87.00	34.00	8.00

PAGE: P	MATERIAL: CPVC	HWC: 150					
Diameter	Equivalent Fitting Lengths in Feet						
(in)	E	T	F	R	C	G	B
	Ell	Tee	45	teeRun	Coup	Gva	Bfy
1.101	5.00	5.00	1.00	1.00	1.00	1.00	4.00
1.598	7.00	8.00	2.00	1.00	1.00	1.00	6.00
2.003	9.00	10.00	2.00	1.00	1.00	2.00	7.00


PAGE: Y	MATERIAL: SCH7	HWC: 120							
Diameter	Equivalent Fitting Lengths in Feet								
(in)	E	T	F	C	B	G	A	D	X
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv	AlmChk	DPVlv	flex
2.185	4.60	15.20	2.40	14.40	6.20	1.00	12.40	12.40	0.00

DATE: 11/6/2025RAULICS\HASS FILES\BUILDING H\H - (4) 16X16 RES49 7PSI.SDF

JOB TITLE: H - (4) 16x16 RES49 7PSI

WATER SUPPLY ANALYSIS


Static: 95.00 psi Resid: 90.00 psi Flow: 1055.0 gpm



DATE: 11/6/2025RAULICS\HASS FILES\BUILDING H\H - (4) 16X16 RES49 7PSI.SDF

JOB TITLE: H - (4) 16x16 RES49 7PSI

WATER SUPPLY CURVE



SMITH FIRE SYSTEMS, INC.
JOB NO. TC25207
BRADLEY HEIGHTS: BUILDING H

SYSTEM # 1

L3 (4) DRY HSW

AUXILIARY HYDRAULIC CALCULATION

DENSITY: 0.1 GPM OVER 4 HEADS

SYSTEM DEMAND AT BASE OF RISER

64.5 GPM AT 43.1 PSI

DATE: 11/6/2025 ILE\HYDRAULICS\HASS FILES\BUILDING H\H - (4) F3QR 7PSI.SDF

JOB TITLE: H - (4) F3QR 7PSI

WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (PSI)	RESID. PRESS. (PSI)	FLOW @ (GPM)	AVAIL. PRESS. (PSI)	TOTAL @ DEMAND (GPM)	REQ'D PRESS. (PSI)
SOURCE	95.0	90.0	1055.0	95.0	64.5	53.9

Available pressure is 41.0 psi (43%) greater than required pressure.

AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	64.5 GPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	0.0 GPM
OTHER HOSE STREAM ALLOWANCES	0.0 GPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	64.5 GPM

NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)
S6	29.3	K= 5.60	8.8	16.6
S7	29.3	K= 5.60	8.2	16.1
S8	29.3	K= 5.60	7.0	14.8
S9	29.3	K= 5.60	9.2	17.0
B3	29.8	- - - -	9.8	- - -
B4	29.8	- - - -	8.8	- - -
M3	29.8	- - - -	10.0	- - -
M4	29.8	- - - -	11.0	- - -
M5	29.8	- - - -	11.0	- - -
31	29.8	- - - -	10.3	- - -
32	32.3	- - - -	10.2	- - -
01	9.5	- - - -	19.7	- - -
02	12.0	- - - -	19.5	- - -
TOR	14.5	- - - -	38.1	- - -
BFP1	7.6	- - - -	41.2	- - -
BFP2	7.6	- - - -	48.2	- - -
UG1	0.0	- - - -	25.0	- - -
UG2	0.0	- - - -	25.4	- - -
UG3	2.5	- - - -	31.2	- - -
UG4	2.5	- - - -	32.8	- - -
UG7	5.0	- - - -	49.5	- - -
UG8	5.0	- - - -	49.5	- - -
UG9	-5.3	- - - -	53.9	- - -
SOURCE	-5.3	SOURCE	53.9	64.5

DATE: 11/6/2025 ILE\HYDRAULICS\HASS FILES\BUILDING H\H - (4) F3QR 7PSI.SDF

JOB TITLE: H - (4) F3QR 7PSI

PIPE DATA

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.	
	NODES	(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	(FT)	SUM.	
							FL/FT		(PSI)	
S6 M3	Pipe: 1					-16.6	1.101 PL	15.00	PF	1.4
	29.3	5.6	8.8	16.6	5.6		150 FTG	E2T	PE	-0.2
	29.8	0.0	10.0	0.0			0.048 TL	30.00	PV	
S7 M3	Pipe: 2					-16.1	1.101 PL	8.50	PF	2.0
	29.3	5.6	8.2	16.1	5.4		150 FTG	5E2T	PE	-0.2
	29.8	0.0	10.0	0.0			0.045 TL	43.50	PV	
S8 B4	Pipe: 3					-14.8	1.101 PL	21.00	PF	2.0
	29.3	5.6	7.0	14.8	5.0		150 FTG	4E2T	PE	-0.2
	29.8	0.0	8.8	0.0			0.039 TL	51.00	PV	
S9 B3	Pipe: 4					-17.0	1.101 PL	6.00	PF	0.8
	29.3	5.6	9.2	17.0	5.7		150 FTG	ET	PE	-0.2
	29.8	0.0	9.8	0.0			0.050 TL	16.00	PV	
B3 M4	Pipe: 5					-17.0	1.101 PL	17.50	PF	1.1
	29.8	0.0	9.8	0.0	5.7		150 FTG	T	PE	0.0
	29.8	0.0	11.0	0.0			0.050 TL	22.50	PV	
B4 M5	Pipe: 6					-14.8	1.101 PL	27.00	PF	2.2
	29.8	0.0	8.8	0.0	5.0		150 FTG	5ET	PE	0.0
	29.8	0.0	11.0	0.0			0.039 TL	57.00	PV	
M5 32	Pipe: 7					-14.8	1.598 PL	20.00	PF	0.3
	29.8	0.0	11.0	0.0	2.4		150 FTG	2ET	PE	-1.1
	32.3	0.0	10.2	0.0			0.006 TL	42.00	PV	
M4 32	Pipe: 8					-17.0	1.598 PL	28.42	PF	0.3
	29.8	0.0	11.0	0.0	2.7		150 FTG	T	PE	-1.1
	32.3	0.0	10.2	0.0			0.008 TL	36.42	PV	
M3 31	Pipe: 9					-32.6	1.598 PL	5.25	PF	0.4
	29.8	0.0	10.0	0.0	5.2		150 FTG	T	PE	0.0
	29.8	0.0	10.3	0.0			0.027 TL	13.25	PV	
31 01	Pipe: 10					-32.6	1.598 PL	20.25	PF	0.6
	29.8	0.0	10.3	0.0	5.2		150 FTG	----	PE	8.8
	9.5	0.0	19.7	0.0			0.027 TL	20.25	PV	
32 02	Pipe: 11					-31.8	1.598 PL	20.25	PF	0.5
	32.3	0.0	10.2	0.0	5.1		150 FTG	----	PE	8.8
	12.0	0.0	19.5	0.0			0.026 TL	20.25	PV	
01 UG1	Pipe: 12					-32.6	1.598 PL	15.00	PF	1.2
	9.5	0.0	19.7	0.0	5.2		150 FTG	2E2T	PE	4.1
	0.0	0.0	25.0	0.0			0.027 TL	45.00	PV	
02 UG2	Pipe: 13					-31.8	1.598 PL	12.00	PF	0.7
	12.0	0.0	19.5	0.0	5.1		150 FTG	2T	PE	5.2
	0.0	0.0	25.4	0.0			0.026 TL	28.00	PV	

DATE: 11/6/2025 FILE\HYDRAULICS\HASS FILES\BUILDING H\H - (4) F3QR 7PSI.SDF
 JOB TITLE: H - (4) F3QR 7PSI

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.	
NODES	(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	FL/FT	(FT)	SUM.	
									(PSI)	
Pipe: 14										
UG1	0.0	0.0	25.0	0.0	3.3	150	FTG	25.08	PF	0.4
UG2	0.0	0.0	25.4	0.0		0.009	TL	43.08	PE	0.0
Pipe: 15										
UG2	0.0	0.0	25.4	0.0	10.3	150	FTG	55.00	PF	6.9
UG3	2.5	0.0	31.2	0.0		0.097	TL	71.00	PE	-1.1
Pipe: 16										
UG3	2.5	0.0	31.2	0.0	6.6	150	FTG	30.33	PF	1.6
UG4	2.5	0.0	32.8	0.0		0.032	TL	48.33	PE	0.0
Pipe: 17										
UG4	2.5	0.0	32.8	0.0	10.3	150	FTG	44.00	PF	10.5
TOR	14.5	0.0	38.1	0.0		0.097	TL	7E2T	PE	-5.2
Pipe: 18										
TOR	14.5	0.0	38.1	0.0	5.5	150	FTG	6.92	PF	0.1
BFP1	7.6	0.0	41.2	0.0		0.021	TL	---	PE	3.0
Pipe: 19										
BFP2	7.6	0.0	48.2	0.0		FIXED PRESSURE LOSS DEVICE				
BFP1	7.6	0.0	41.2	0.0		7.0 psi,	64.5 gpm			
Pipe: 20										
BFP2	7.6	0.0	48.2	0.0	1.6	140	FTG	50.50	PF	0.1
UG7	5.0	0.0	49.5	0.0		0.001	TL	ET2G	PE	1.1
Pipe: 21										
UG7	5.0	0.0	49.5	0.0	0.4	140	FTG	95.00	PF	0.0
UG8	5.0	0.0	49.5	0.0		0.000	TL	TG	PE	0.0
Pipe: 22										
UG8	5.0	0.0	49.5	0.0	0.2	140	FTG	148.00	PF	0.0
UG9	-5.3	0.0	53.9	0.0		0.000	TL	TFG	PE	4.5
Pipe: 23										
UG9	-5.3	0.0	53.9	0.0	0.7	140	FTG	567.00	PF	0.0
SOURCE	-5.3	SRCE	53.9	(N/A)		0.000	TL	EG	PE	0.0
								36.00	PV	

NOTES (HASS):

- Calculations were performed by the HASS 2023 D computer program in accordance with NFPA (2020) under license no. 64621553 granted by HRS Systems, Inc.
 208 Southside Square
 Petersburg, TN 37144
 (931) 659-9760
- The system has been calculated to provide an average imbalance at each node of 0.002 gpm and a maximum imbalance at any node of 0.056 gpm.

DATE: 11/6/2025 ILE\HYDRAULICS\HASS FILES\BUILDING H\H - (4) F3QR 7PSI.SDF
 JOB TITLE: H - (4) F3QR 7PSI

(3) Total pressure at each node is used in balancing the system.
 Maximum water velocity is 10.3 ft/sec at pipe 17.

(4) Items listed in bold print on the cover sheet

are automatically transferred from the calculation report.

(5) Available pressure at source node SOURCE under full flow conditions is
 94.94 psi with a flow of 99.78 gpm.

(6) PIPE FITTINGS TABLE

User Pipe Table Name: SMITH

PAGE: D	MATERIAL: DI		HWC: 140			
Diameter	Equivalent Fitting Lengths in Feet					
(in)	E	T	F	C	B	G
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv
4.100	8.00	27.00	6.00	30.00	20.00	3.00
6.160	12.00	40.00	10.00	43.00	16.00	4.00
8.270	18.00	47.00	12.00	60.00	20.00	6.00
12.340	24.00	80.00	19.00	87.00	34.00	8.00

PAGE: P	MATERIAL: CPVC		HWC: 150				
Diameter	Equivalent Fitting Lengths in Feet						
(in)	E	T	F	R	C	G	B
	Ell	Tee	45	teeRun	Coup	Gva	Bfy
1.101	5.00	5.00	1.00	1.00	1.00	1.00	4.00
1.598	7.00	8.00	2.00	1.00	1.00	1.00	6.00
2.003	9.00	10.00	2.00	1.00	1.00	2.00	7.00


PAGE: Y	MATERIAL: SCH7		HWC: 120							
Diameter	Equivalent Fitting Lengths in Feet									
(in)	E	T	F	C	B	G	A	D	X	
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv	AlmChk	DPVlv	flx	
2.185	4.60	15.20	2.40	14.40	6.20	1.00	12.40	12.40	0.00	

DATE: 11/6/2025 ILE\HYDRAULICS\HASS FILES\BUILDING H\H - (4) F3QR 7PSI.SDF

JOB TITLE: H - (4) F3QR 7PSI

WATER SUPPLY ANALYSIS


Static: 95.00 psi Resid: 90.00 psi Flow: 1055.0 gpm



DATE: 11/6/2025 ILE\HYDRAULICS\HASS FILES\BUILDING H\H - (4) F3QR 7PSI.SDF

JOB TITLE: H - (4) F3QR 7PSI

WATER SUPPLY CURVE



**SMITH FIRE SYSTEMS, INC.
JOB NO. TC25207
BRADLEY HEIGHTS: BUILDING H**

SYSTEM # 1

L3 (2) HEAD COMPARTMENT

AUXILIARY HYDRAULIC CALCULATION

DENSITY: 0.05 GPM OVER 2 HEADS

SYSTEM DEMAND AT BASE OF RISER

34.8 GPM AT 30.7 PSI

DATE: 11/6/2025AULICS\HASS FILES\BUILDING H\H - (2) 18X18 RES49 12PSI.SDF

JOB TITLE: H - (2) 18x18 RES49 12PSI

WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (PSI)	RESID. PRESS. (PSI)	FLOW @ (GPM)	AVAIL. PRESS. (PSI)	TOTAL @ DEMAND (GPM)	REQ'D PRESS. (PSI)
SOURCE	95.0	90.0	1055.0	95.0	34.8	44.0

Available pressure is 51.0 psi (54%) greater than required pressure.

AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	34.8 GPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	0.0 GPM
OTHER HOSE STREAM ALLOWANCES	0.0 GPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	34.8 GPM

NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)
S10	29.3	K= 4.90	12.0	17.0
S11	29.3	K= 4.90	13.3	17.9
B4	29.8	- - - -	13.0	- - -
B5	29.8	- - - -	13.4	- - -
M4	29.8	- - - -	15.4	- - -
M5	29.8	- - - -	15.9	- - -
32	32.3	- - - -	14.8	- - -
02	12.0	- - - -	24.2	- - -
TOR	14.5	- - - -	27.7	- - -
BFP1	7.6	- - - -	30.7	- - -
BFP2	7.6	- - - -	37.7	- - -
UG3	2.5	- - - -	29.5	- - -
UG4	2.5	- - - -	30.0	- - -
UG7	5.0	- - - -	39.6	- - -
UG8	5.0	- - - -	39.6	- - -
UG9	-5.2	- - - -	44.0	- - -
SOURCE	-5.2	SOURCE	44.0	34.8

DATE: 11/6/2025AULICS\HASS FILES\BUILDING H\H - (2) 18X18 RES49 12PSI.SDF
 JOB TITLE: H - (2) 18x18 RES49 12PSI

PIPE DATA

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	VEL (FPS)	DIA (IN)	LENGTH	PRESS.	
	NODES	(FT)	(K)	(PSI)	(GPM)			HW (C)	(FT)	SUM.	
								FL/FT		(PSI)	
Pipe: 1											
S10		29.3	4.9	12.0	17.0	-17.0	5.7	1.101 PL	9.17	PF	1.2
B4		29.8	0.0	13.0	0.0			150 FTG	3E	PE	-0.2
								0.050 TL	24.17	PV	
Pipe: 2											
S11		29.3	4.9	13.3	17.9	-17.9	6.0	1.101 PL	0.50	PF	0.3
B5		29.8	0.0	13.4	0.0			150 FTG	T	PE	-0.2
								0.055 TL	5.50	PV	
Pipe: 3											
B4		29.8	0.0	13.0	0.0	-17.0	5.7	1.101 PL	27.00	PF	2.9
M5		29.8	0.0	15.9	0.0			150 FTG	5ET	PE	0.0
								0.050 TL	57.00	PV	
Pipe: 4											
B5		29.8	0.0	13.4	0.0	-17.9	6.0	1.101 PL	12.42	PF	2.1
M4		29.8	0.0	15.4	0.0			150 FTG	4ET	PE	0.0
								0.055 TL	37.42	PV	
Pipe: 5											
M4		29.8	0.0	15.4	0.0	-17.9	2.9	1.598 PL	30.92	PF	0.5
32		32.3	0.0	14.8	0.0			150 FTG	2ET	PE	-1.1
								0.009 TL	52.92	PV	
Pipe: 6											
M5		29.8	0.0	15.9	0.0	-17.0	1.2	2.423 PL	22.50	PF	0.1
32		32.3	0.0	14.8	0.0			150 FTG	2ET	PE	-1.1
								0.001 TL	58.50	PV	
Pipe: 7											
32		32.3	0.0	14.8	0.0	-34.8	5.6	1.598 PL	20.25	PF	0.6
02		12.0	0.0	24.2	0.0			150 FTG	----	PE	8.8
								0.031 TL	20.25	PV	
Pipe: 8											
02		12.0	0.0	24.2	0.0	-34.8	5.6	1.598 PL	15.25	PF	1.2
UG3		2.5	0.0	29.5	0.0			150 FTG	2ET	PE	4.1
								0.031 TL	37.25	PV	
Pipe: 9											
UG3		2.5	0.0	29.5	0.0	-34.8	3.5	2.003 PL	30.33	PF	0.5
UG4		2.5	0.0	30.0	0.0			150 FTG	2E	PE	0.0
								0.010 TL	48.33	PV	
Pipe: 10											
UG4		2.5	0.0	30.0	0.0	-34.8	5.6	1.598 PL	44.00	PF	2.9
TOR		14.5	0.0	27.7	0.0			150 FTG	7E	PE	-5.2
								0.031 TL	93.00	PV	
Pipe: 11											
TOR		14.5	0.0	27.7	0.0	-34.8	3.0	2.185 PL	6.92	PF	0.0
BFP1		7.6	0.0	30.7	0.0			150 FTG	----	PE	3.0
								0.007 TL	6.92	PV	
Pipe: 12											
BFP2		7.6	0.0	37.7	0.0	FIXED PRESSURE LOSS DEVICE					
BFP1		7.6	0.0	30.7	0.0	7.0 psi, 34.8 gpm					
Pipe: 13											
BFP2		7.6	0.0	37.7	0.0	-34.8	3.5	2.003 PL	50.50	PF	0.8
UG7		5.0	0.0	39.6	0.0			150 FTG	ET2G	PE	1.1
								0.010 TL	73.50	PV	

DATE: 11/6/2025AULICS\HASS FILES\BUILDING H\H - (2) 18X18 RES49 12PSI.SDF
 JOB TITLE: H - (2) 18x18 RES49 12PSI

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.
NODES	(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	FL/FT	(FT)	SUM.
									(PSI)
Pipe: 14					-34.8	8.270	PL	95.00	PF 0.0
UG7	5.0	0.0	39.6	0.0	0.2	140	FTG	TG	PE 0.0
UG8	5.0	0.0	39.6	0.0		0.000	TL	148.00	PV
Pipe: 15					-34.8	12.340	PL	460.00	PF 0.0
UG8	5.0	0.0	39.6	0.0	0.1	140	FTG	TFG	PE 4.4
UG9	-5.2	0.0	44.0	0.0		0.000	TL	567.00	PV
Pipe: 16					-34.8	6.160	PL	20.00	PF 0.0
UG9	-5.2	0.0	44.0	0.0	0.4	140	FTG	EG	PE 0.0
SOURCE	-5.2	SRCE	44.0	(N/A)		0.000	TL	36.00	PV

NOTES (HASS):

- Calculations were performed by the HASS 2023 D computer program in accordance with NFPA (2020) under license no. 64621553 granted by
 HRS Systems, Inc.
 208 Southside Square
 Petersburg, TN 37144
 (931) 659-9760
- The system has been calculated to provide an average imbalance at each node of 0.010 gpm and a maximum imbalance at any node of 0.154 gpm.
- Total pressure at each node is used in balancing the system. Maximum water velocity is 6.0 ft/sec at pipe 4.
- Items listed in bold print on the cover sheet
 are automatically transferred from the calculation report.
- Available pressure at source node SOURCE under full flow conditions is 94.97 psi with a flow of 64.57 gpm.
- PIPE FITTINGS TABLE

User Pipe Table Name: SMITH

DATE: 11/6/2025AULICS\HASS FILES\BUILDING H\H - (2) 18X18 RES49 12PSI.SDF

JOB TITLE: H - (2) 18x18 RES49 12PSI

PAGE: D MATERIAL: DI HWC: 140

Diameter (in)	Equivalent Fitting Lengths in Feet					
	E	T	F	C	B	G
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv
6.160	12.00	40.00	10.00	43.00	16.00	4.00
8.270	18.00	47.00	12.00	60.00	20.00	6.00
12.340	24.00	80.00	19.00	87.00	34.00	8.00

PAGE: P MATERIAL: CPVC HWC: 150

Diameter (in)	Equivalent Fitting Lengths in Feet						
	E	T	F	R	C	G	B
	Ell	Tee	45	teeRun	Coup	Gva	Bfy
1.101	5.00	5.00	1.00	1.00	1.00	1.00	4.00
1.598	7.00	8.00	2.00	1.00	1.00	1.00	6.00
2.003	9.00	10.00	2.00	1.00	1.00	2.00	7.00
2.423	12.00	12.00	3.00	2.00	2.00	2.00	0.00

PAGE: Y MATERIAL: SCH7 HWC: 120


Diameter (in)	Equivalent Fitting Lengths in Feet								
	E	T	F	C	B	G	A	D	X
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv	AlmChk	DPVlv	flex
2.185	4.60	15.20	2.40	14.40	6.20	1.00	12.40	12.40	0.00

DATE: 11/6/2025AULICS\HASS FILES\BUILDING H\H - (2) 18X18 RES49 12PSI.SDF

JOB TITLE: H - (2) 18x18 RES49 12PSI

WATER SUPPLY ANALYSIS

Static: 95.00 psi Resid: 90.00 psi Flow: 1055.0 gpm




Note: (1) Dashed Lines indicate extrapolated values from Test Results

DATE: 11/6/2025AULICS\HASS FILES\BUILDING H\H - (2) 18X18 RES49 12PSI.SDF

JOB TITLE: H - (2) 18x18 RES49 12PSI

WATER SUPPLY CURVE



**SMITH FIRE SYSTEMS, INC.
JOB NO. TC25207
BRADLEY HEIGHTS: BUILDING H**

SYSTEM # 1

L3 (1) HEAD COMPARTMENT

AUXILIARY HYDRAULIC CALCULATION

DENSITY: 0.05 GPM OVER 1 HEADS

SYSTEM DEMAND AT BASE OF RISER

20 GPM AT 32.9 PSI

DATE: 11/6/2025 LICs\HASS FILES\BUILDING H\H - (1) 20X20 RES49 16.7PSI.SDF
 JOB TITLE: H - (1) 20x20 RES49 16.7PSI

WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (PSI)	RESID. PRESS. (PSI)	FLOW @ (GPM)	AVAIL. PRESS. (PSI)	TOTAL @ DEMAND (GPM)	REQ'D PRESS. (PSI)
SOURCE	95.0	90.0	1055.0	95.0	20.0	45.5

Available pressure is 49.5 psi (52%) greater than required pressure.

AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	20.0 GPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	0.0 GPM
OTHER HOSE STREAM ALLOWANCES	0.0 GPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	20.0 GPM

NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)
S1	29.3	K= 4.90	16.7	20.0
M1	29.8	- - - -	19.8	- - -
31	29.8	- - - -	20.1	- - -
01	9.5	- - - -	29.5	- - -
TOR	14.5	- - - -	29.9	- - -
BFP1	7.6	- - - -	32.9	- - -
BFP2	7.6	- - - -	39.9	- - -
UG1	0.0	- - - -	33.9	- - -
UG2	0.0	- - - -	34.1	- - -
UG3	2.5	- - - -	33.8	- - -
UG4	2.5	- - - -	34.0	- - -
UG7	5.0	- - - -	41.0	- - -
UG8	5.0	- - - -	41.0	- - -
UG9	-5.2	- - - -	45.5	- - -
SOURCE	-5.2	SOURCE	45.5	20.0

DATE: 11/6/2025 LICs\HASS FILES\BUILDING H\H - (1) 20X20 RES49 16.7PSI.SDF
 JOB TITLE: H - (1) 20x20 RES49 16.7PSI

PIPE DATA

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.	
	NODES	(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	(FT)	SUM.	
							FL/FT		(PSI)	
S1 M1	Pipe: 1					-20.0	1.101 PL	18.58	PF	3.3
	29.3	4.9	16.7	20.0	6.7	150	FTG	5ET	PE	-0.2
	29.8	0.0	19.8	0.0		0.068	TL	48.58	PV	
M1 31	Pipe: 2					-20.0	1.598 PL	20.50	PF	0.3
	29.8	0.0	19.8	0.0	3.2	150	FTG	T	PE	0.0
	29.8	0.0	20.1	0.0		0.011	TL	28.50	PV	
31 01	Pipe: 3					-20.0	1.598 PL	20.25	PF	0.6
	29.8	0.0	20.1	0.0	3.2	150	FTG	4ET	PE	8.8
	9.5	0.0	29.5	0.0		0.011	TL	56.25	PV	
01 UG1	Pipe: 4					-20.0	1.598 PL	15.00	PF	0.3
	9.5	0.0	29.5	0.0	3.2	150	FTG	2E	PE	4.1
	0.0	0.0	33.9	0.0		0.011	TL	29.00	PV	
UG1 UG2	Pipe: 5					-20.0	2.003 PL	25.08	PF	0.2
	0.0	0.0	33.9	0.0	2.0	150	FTG	2E	PE	0.0
	0.0	0.0	34.1	0.0		0.004	TL	43.08	PV	
UG2 UG3	Pipe: 6					-20.0	1.598 PL	55.00	PF	0.8
	0.0	0.0	34.1	0.0	3.2	150	FTG	2T	PE	-1.1
	2.5	0.0	33.8	0.0		0.011	TL	71.00	PV	
UG3 UG4	Pipe: 7					-20.0	2.003 PL	30.33	PF	0.2
	2.5	0.0	33.8	0.0	2.0	150	FTG	2E	PE	0.0
	2.5	0.0	34.0	0.0		0.004	TL	48.33	PV	
UG4 TOR	Pipe: 10					-20.0	1.598 PL	50.00	PF	1.1
	2.5	0.0	34.0	0.0	3.2	150	FTG	7E	PE	-5.2
	14.5	0.0	29.9	0.0		0.011	TL	99.00	PV	
TOR BFP1	Pipe: 11					-20.0	2.185 PL	6.92	PF	0.0
	14.5	0.0	29.9	0.0	1.7	150	FTG	----	PE	3.0
	7.6	0.0	32.9	0.0		0.002	TL	6.92	PV	
BFP2 BFP1	Pipe: 12						FIXED PRESSURE LOSS DEVICE			
	7.6	0.0	39.9	0.0		7.0 psi, 20.0 gpm				
	7.6	0.0	32.9	0.0						
BFP2 UG7	Pipe: 13					-20.0	4.100 PL	50.50	PF	0.0
	7.6	0.0	39.9	0.0	0.5	140	FTG	ET2G	PE	1.1
	5.0	0.0	41.0	0.0		0.000	TL	91.50	PV	
UG7 UG8	Pipe: 14					-20.0	8.270 PL	95.00	PF	0.0
	5.0	0.0	41.0	0.0	0.1	140	FTG	TG	PE	0.0
	5.0	0.0	41.0	0.0		0.000	TL	148.00	PV	
UG8 UG9	Pipe: 15					-20.0	12.340 PL	460.00	PF	0.0
	5.0	0.0	41.0	0.0	0.1	140	FTG	TFG	PE	4.4
	-5.2	0.0	45.5	0.0		0.000	TL	567.00	PV	

DATE: 11/6/2025 LICHS\HASS FILES\BUILDING H\H - (1) 20X20 RES49 16.7PSI.SDF
 JOB TITLE: H - (1) 20x20 RES49 16.7PSI

PIPE TAG					Q (GPM)	DIA (IN)	LENGTH	PRESS.	
END	ELEV.	NOZ.	PT	DISC.	VEL (FPS)	HW (C)	(FT)	SUM.	
NODES	(FT)	(K)	(PSI)	(GPM)		FL/FT		(PSI)	
Pipe: 16					-20.0	6.160	PL 20.00	PF	0.0
UG9	-5.2	0.0	45.5	0.0	0.2	140	FTG EG	PE	0.0
SOURCE	-5.2	SRCE	45.5	(N/A)		0.000	TL 36.00	PV	

NOTES (HASS):

- (1) Calculations were performed by the HASS 2023 D computer program in accordance with NFPA (2020) under license no. 64621553 granted by
 HRS Systems, Inc.
 208 Southside Square
 Petersburg, TN 37144
 (931) 659-9760
- (2) The system has been calculated to provide an average imbalance at each node of 0.014 gpm and a maximum imbalance at any node of 0.189 gpm.
- (3) Total pressure at each node is used in balancing the system. Maximum water velocity is 6.7 ft/sec at pipe 1.
- (4) Items listed in bold print on the cover sheet
 are automatically transferred from the calculation report.
- (5) Available pressure at source node SOURCE under full flow conditions is 94.99 psi with a flow of 35.74 gpm.
- (6) PIPE FITTINGS TABLE

User Pipe Table Name: SMITH

PAGE: D	MATERIAL: DI	HWC: 140				
Diameter	Equivalent Fitting Lengths in Feet					
(in)	E	T	F	C	B	G
	Ell	Tee	45 ChkVlv	BfyVlv	GatVlv	
4.100	8.00	27.00	6.00	30.00	20.00	3.00
6.160	12.00	40.00	10.00	43.00	16.00	4.00
8.270	18.00	47.00	12.00	60.00	20.00	6.00
12.340	24.00	80.00	19.00	87.00	34.00	8.00

DATE: 11/6/2025 LICs\HASS FILES\BUILDING H\H - (1) 20X20 RES49 16.7PSI.SDF
 JOB TITLE: H - (1) 20x20 RES49 16.7PSI

PAGE: P	MATERIAL: CPVC		HWC: 150				
Diameter	Equivalent Fitting Lengths in Feet						
(in)	E	T	F	R	C	G	B
	Ell	Tee	45 teeRun	Coup	Gva	Bfy	
1.101	5.00	5.00	1.00	1.00	1.00	1.00	4.00
1.598	7.00	8.00	2.00	1.00	1.00	1.00	6.00
2.003	9.00	10.00	2.00	1.00	1.00	2.00	7.00


PAGE: Y	MATERIAL: SCH7		HWC: 120						
Diameter	Equivalent Fitting Lengths in Feet								
(in)	E	T	F	C	B	G	A	D	X
	Ell	Tee	45 ChkVlv	BfyVlv	GatVlv	AlmChk	DPVlv	fleX	
2.185	4.60	15.20	2.40	14.40	6.20	1.00	12.40	12.40	0.00

DATE: 11/6/2025 LICs\HASS FILES\BUILDING H\H - (1) 20X20 RES49 16.7PSI.SDF

JOB TITLE: H - (1) 20x20 RES49 16.7PSI

WATER SUPPLY ANALYSIS

Static: 95.00 psi Resid: 90.00 psi Flow: 1055.0 gpm



DATE: 11/6/2025 LICs\HASS FILES\BUILDING H\H - (1) 20X20 RES49 16.7PSI.SDF

JOB TITLE: H - (1) 20x20 RES49 16.7PSI

WATER SUPPLY CURVE

