


**SMITH FIRE SYSTEMS, INC**

1106 54TH AVENUE EAST TACOMA, WASHINGTON 98424

(253) 926-1880 Fax (253) 926-2350

CONTR. REG. NO. SMITHFS1360T

**GENERAL / HYDRAULIC CALCULATION INFORMATION SHEET**

PROJECT NAME:	BRADLEY HEIGHTS	JOB NO. :	TC25207	CONTRACTOR : RUSH COMMERCIAL CONSTR. AHJ : PUYALLUP
	BUILDING B	DATE:	10/17/2025	
ADDRESS:	206 27TH AVE SE	BY:	A. RIDEOUT	
	PUYALLUP, WA 98374			

SYSTEM DESIGNATION: **SYSTEM #1 -L3 (4) HEAD COMPARTMENT**DESIGN PER: **NFPA 13R (2019 EDITION)**OCCUPANCY CLASSIFICATION: **RESIDENTIAL****DESIGN CRITERIA:**NFPA SECTION: **7.2.3**
AREA MODIFIER **N/A**SPRINKLER MANUFACTURER: **RELIABLE**
K-FACTOR: **4.9K**
MODEL: **F1RES49**
TEMPERATURE: **155°**
RESPONSE TYPE: **QR**SYSTEM TYPE: **WET**
MAX CEILING HEIGHT: **9'-1"**
CEILING HEIGHT: **9'-1"**
ROOF SLOPE: **4:12**
CEILING SLOPE: **2:12**TOTAL SPRINKLERS CALCULATED: **4**
MAX AREA OF COVERAGE PER SPRINKLER: **256 SQ. FT**
MAX DISTANCE BETWEEN SPRINKLERS: **16 FT**FIRE PUMP: **N**
RATED CAPACITY OF PUMP: **N/A****DESIGN AREA**

THE (4) HYDRAULICALLY MOST DEMANDING ADJACENT SPRINKLERS DELIVERING .05 GPM/SQ. FT. OR PER THE SPRINKLER LISTING, WHICHEVER IS MORE DEMANDING.

ALLOWANCES INCLUDED IN CALCULATIONS:OUTSIDE HOSE **0 GPM**ADDED AT:

CITY CONNECTION

WATER SUPPLY:	ELEVATION OF TEST: 0 FT.	ELEVATION OF LEVEL 1: 0 FT.	MAIN DRAIN TEST:
STATIC 95 PSI	DATE OF TEST: 4/19/2001		S: R:
RESIDUAL 90 PSI	DATA PROVIDED BY: FRUITLAND WATER		INSPECTORS TEST:
FLOW 1055 GPM	LOCATION OF TEST: FH 523 @ 207 27TH AVE SE		TRIP TIME:

WET SYSTEM NUMBER 1

AREA	SQ. FT.	SPRINKLERS
BASEMENT	2605	23
FLOOR 1	4960	49
FLOOR 2	4960	48
FLOOR 3	4960	52
TOTAL:	17485	172

NOTES:**MOST DEMANDING AREA: SYS. 1**

MOST DEMANDING (4) SPRINKLER(S) AT 7 PSI

BASE OF RISER: 61.8 GPM REQUIRED AT 59.0 PSI**SUMMARY:** 61.8 GPM REQUIRED AT 83.1 PSIAT CONNECTION TO **SOURCE**(INCLUDING **0 GPM** FOR HOSE STREAMS)



SMITH FIRE SYSTEMS, INC.

WATER SUPPLY DATA

STATIC 95 PSI
RESIDUAL 90 PSI
FLOWING 1055 GPM

JOB NAME BRADLEY HEIGHTS - BUILDING B

ADDRESS 202 27TH AVE SE

DATE PUYALLUP, WA 98374

JOB NO. TC25207

SYSTEM/AREA SYSTEM 1: (4) HEAD COMPARTMENT @16X16


MOST DEMANDING AREA: SYS. 1

MOST DEMANDING (4) SPRINKLER(S) AT 7 PSI

BASE OF RISER: 61.8 GPM REQUIRED AT 59.0 PSI

SUMMARY: 61.8 GPM REQUIRED AT 83.1 PSI

AT CONNECTION TO SOURCE
(INCLUDING 0 GPM FOR HOSE STREAMS)



DATE: 10/30/2025AULICS\HASS FILES\BUILDING B\B - (4) 16X16 RES49 7PSI.SDF

JOB TITLE: B - (4) 16x16 RES49 7PSI

WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (PSI)	RESID. PRESS. (PSI)	FLOW @ (GPM)	AVAIL. PRESS. (PSI)	TOTAL @ DEMAND (GPM)	REQ'D PRESS. (PSI)
SOURCE	95.0	90.0	1055.0	95.0	61.8	83.1

Available pressure is 11.9 psi (12%) greater than required pressure.

AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	61.8 GPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	0.0 GPM
OTHER HOSE STREAM ALLOWANCES	0.0 GPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	61.8 GPM

NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)
S2	39.3	K= 4.90	7.1	13.0
S3	39.3	K= 4.90	7.0	13.0
S4	39.3	K= 4.90	13.0	17.7
S5	39.3	K= 4.90	13.6	18.1
B1	39.8	- - - -	7.3	- - -
M1	39.8	- - - -	13.9	- - -
M2	39.8	- - - -	14.2	- - -
M3	39.8	- - - -	14.3	- - -
M4	39.8	- - - -	14.8	- - -
31	39.8	- - - -	15.0	- - -
01	9.6	- - - -	37.5	- - -
TOR	12.0	- - - -	58.3	- - -
BFP1	8.1	- - - -	60.1	- - -
BFP2	8.1	- - - -	67.1	- - -
BOR	10.5	- - - -	59.0	- - -
UG1	0.0	- - - -	70.7	- - -
UG2	0.0	- - - -	70.7	- - -
UG3	-28.6	- - - -	83.1	- - -
SOURCE	-28.6	SOURCE	83.1	61.8

DATE: 10/30/2025 AULICS\HASS FILES\BUILDING B\B - (4) 16X16 RES49 7PSI.SDF
 JOB TITLE: B - (4) 16x16 RES49 7PSI

PIPE DATA

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	VEL (FPS)	DIA (IN)	LENGTH	PRESS.	
	NODES	(FT)	(K)	(PSI)	(GPM)			HW (C)	(FT)	SUM.	
								FL/FT		(PSI)	
Pipe: 1											
S2		39.3	4.9	7.1	13.0	-13.0	4.4	1.101	4.25	PF	0.4
B1		39.8	0.0	7.3	0.0			150	2T	PE	-0.2
								0.031	14.25	PV	
Pipe: 2											
S3		39.3	4.9	7.0	13.0	-13.0	4.4	1.101	6.25	PF	0.5
B1		39.8	0.0	7.3	0.0			150	ET	PE	-0.2
								0.030	16.25	PV	
Pipe: 3											
B1		39.8	0.0	7.3	0.0	-26.0	8.8	1.101	28.33	PF	7.0
M3		39.8	0.0	14.3	0.0			150	6ET	PE	0.0
								0.110	63.33	PV	
Pipe: 4											
S4		39.3	4.9	13.0	17.7	-17.7	6.0	1.101	11.25	PF	1.2
M1		39.8	0.0	13.9	0.0			150	ET	PE	-0.2
								0.054	21.25	PV	
Pipe: 5											
S5		39.3	4.9	13.6	18.1	-18.1	6.1	1.101	14.00	PF	1.4
M4		39.8	0.0	14.8	0.0			150	2T	PE	-0.2
								0.057	24.00	PV	
Pipe: 6											
M1		39.8	0.0	13.9	0.0	-17.7	3.7	1.394	12.75	PF	0.2
M2		39.8	0.0	14.2	0.0			150	----	PE	0.0
								0.017	12.75	PV	
Pipe: 7											
M2		39.8	0.0	14.2	0.0	-17.7	3.7	1.394	6.00	PF	0.1
M3		39.8	0.0	14.3	0.0			150	----	PE	0.0
								0.017	6.00	PV	
Pipe: 8											
M3		39.8	0.0	14.3	0.0	-43.7	9.2	1.394	1.75	PF	0.7
31		39.8	0.0	15.0	0.0			150	T	PE	0.0
								0.091	7.75	PV	
Pipe: 9											
M4		39.8	0.0	14.8	0.0	-18.1	3.8	1.394	5.25	PF	0.2
31		39.8	0.0	15.0	0.0			150	T	PE	0.0
								0.018	11.25	PV	
Pipe: 10											
31		39.8	0.0	15.0	0.0	-61.8	13.0	1.394	30.25	PF	9.4
01		9.6	0.0	37.5	0.0			150	4E	PE	13.1
								0.174	54.25	PV	
Pipe: 11											
01		9.6	0.0	37.5	0.0	-61.8	13.0	1.394	71.75	PF	21.8
TOR		12.0	0.0	58.3	0.0			150	8ET	PE	-1.0
								0.174	125.75	PV	
Pipe: 12											
TOR		12.0	0.0	58.3	0.0	-61.8	5.3	2.185	1.50	PF	0.0
BOR		10.5	0.0	59.0	0.0			150	----	PE	0.6
								0.019	1.50	PV	
Pipe: 13											
BOR		10.5	0.0	59.0	0.0	-61.8	5.3	2.185	2.42	PF	0.1
BFP1		8.1	0.0	60.1	0.0			120	----	PE	1.0
								0.029	2.42	PV	

DATE: 10/30/2025AULICS\HASS FILES\BUILDING B\B - (4) 16X16 RES49 7PSI.SDF
 JOB TITLE: B - (4) 16x16 RES49 7PSI

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.
NODES	(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	FL/FT	(FT)	SUM.
									(PSI)
Pipe: 14									
BFP2	8.1	0.0	67.1	0.0					
BFP1	8.1	0.0	60.1	0.0					
Pipe: 15									
BFP2	8.1	0.0	67.1	0.0	1.5	4.100	PL	60.00	PF 0.1
UG1	0.0	0.0	70.7	0.0		140	FTG	2ET2G	PE 3.5
						0.001	TL	109.00	PV
Pipe: 16									
UG1	0.0	0.0	70.7	0.0	0.4	8.270	PL	390.00	PF 0.0
UG2	0.0	0.0	70.7	0.0		140	FTG	TBG	PE 0.0
						0.000	TL	463.00	PV
Pipe: 17									
UG2	0.0	0.0	70.7	0.0	0.2	12.340	PL	920.00	PF 0.0
UG3	-28.6	0.0	83.1	0.0		140	FTG	F	PE 12.4
						0.000	TL	939.00	PV
Pipe: 18									
UG3	-28.6	0.0	83.1	0.0	0.7	6.160	PL	15.00	PF 0.0
SOURCE	-28.6	SRCE	83.1	(N/A)		140	FTG	TG	PE 0.0
						0.000	TL	59.00	PV

NOTES (HASS):

- Calculations were performed by the HASS 2023 D computer program in accordance with NFPA (2020) under license no. 64621553 granted by
 HRS Systems, Inc.
 208 Southside Square
 Petersburg, TN 37144
 (931) 659-9760
- The system has been calculated to provide an average imbalance at each node of 0.005 gpm and a maximum imbalance at any node of 0.089 gpm.
- Total pressure at each node is used in balancing the system. Maximum water velocity is 13.0 ft/sec at pipe 10.
- Items listed in bold print on the cover sheet
 are automatically transferred from the calculation report.
- Available pressure at source node SOURCE under full flow conditions is 94.97 psi with a flow of 69.63 gpm.

DATE: 10/30/2025AULICS\HASS FILES\BUILDING B\B - (4) 16X16 RES49 7PSI.SDF

JOB TITLE: B - (4) 16x16 RES49 7PSI

(6) PIPE FITTINGS TABLE

User Pipe Table Name: SMITH

PAGE: D MATERIAL: DI HWC: 140

Diameter (in)	Equivalent Fitting Lengths in Feet					
	E	T	F	C	B	G
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv
4.100	8.00	27.00	6.00	30.00	20.00	3.00
6.160	12.00	40.00	10.00	43.00	16.00	4.00
8.270	18.00	47.00	12.00	60.00	20.00	6.00
12.340	24.00	80.00	19.00	87.00	34.00	8.00

PAGE: P MATERIAL: CPVC HWC: 150

Diameter (in)	Equivalent Fitting Lengths in Feet						
	E	T	F	R	C	G	B
	Ell	Tee	45	teeRun	Coup	Gva	Bfy
1.101	5.00	5.00	1.00	1.00	1.00	1.00	4.00
1.394	6.00	6.00	2.00	1.00	1.00	1.00	5.00

PAGE: Y MATERIAL: SCH7 HWC: 120


Diameter (in)	Equivalent Fitting Lengths in Feet								
	E	T	F	C	B	G	A	D	X
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv	AlmChk	DPVlv	flex
2.185	4.60	15.20	2.40	14.40	6.20	1.00	12.40	12.40	0.00

DATE: 10/30/2025AULICS\HASS FILES\BUILDING B\B - (4) 16X16 RES49 7PSI.SDF

JOB TITLE: B - (4) 16x16 RES49 7PSI

WATER SUPPLY ANALYSIS


Static: 95.00 psi Resid: 90.00 psi Flow: 1055.0 gpm



DATE: 10/30/2025AULICS\HASS FILES\BUILDING B\B - (4) 16X16 RES49 7PSI.SDF

JOB TITLE: B - (4) 16x16 RES49 7PSI

WATER SUPPLY CURVE



SMITH FIRE SYSTEMS, INC.
JOB NO. TC25207
BRADLEY HEIGHTS: BUILDING B

SYSTEM # 1

L3 (4) DRY HSW

AUXILIARY HYDRAULIC CALCULATION

DENSITY: 0.1 GPM OVER 4 HEADS

SYSTEM DEMAND AT BASE OF RISER

67 GPM AT 50.5 PSI

DATE: 10/30/2025SS FILES\BUILDING B\AUX CALCS\B - (4) F3QR56 HSW 7PSI.SDF

JOB TITLE: (4) F3QR HSW 7PSI

WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (PSI)	RESID. PRESS. (PSI)	FLOW @ (GPM)	AVAIL. PRESS. (PSI)	TOTAL @ DEMAND (GPM)	REQ'D PRESS. (PSI)
SOURCE	95.0	90.0	1055.0	95.0	67.0	74.7

Available pressure is 20.2 psi (21%) greater than required pressure.

AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	67.0 GPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	0.0 GPM
OTHER HOSE STREAM ALLOWANCES	0.0 GPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	67.0 GPM

NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)
S6	39.0	K= 5.60	7.0	14.8
S7	39.0	K= 5.60	8.1	15.9
S8	39.8	K= 5.60	10.3	18.0
S9	39.0	K= 5.60	10.8	18.4
B2	39.8	- - - -	8.6	- - -
M5	39.8	- - - -	14.9	- - -
M4	39.8	- - - -	12.2	- - -
32	39.8	- - - -	15.4	- - -
31	39.8	- - - -	12.9	- - -
02	9.6	- - - -	30.2	- - -
01	9.6	- - - -	28.4	- - -
TOR	12.0	- - - -	48.8	- - -
BFP1	8.1	- - - -	51.7	- - -
BFP2	8.1	- - - -	58.7	- - -
BOR	10.5	- - - -	50.5	- - -
UG1	0.0	- - - -	62.3	- - -
UG2	0.0	- - - -	62.3	- - -
UG3	-28.6	- - - -	74.7	- - -
SOURCE	-28.6	SOURCE	74.7	67.0

DATE: 10/30/2025SS FILES\BUILDING B\AUX CALCS\B - (4) F3QR56 HSW 7PSI.SDF

JOB TITLE: (4) F3QR HSW 7PSI

PIPE DATA

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	VEL (FPS)	DIA (IN)	LENGTH	PRESS.	
NODES		(FT)	(K)	(PSI)	(GPM)			HW (C)	(FT)	SUM.	
								FL/FT		(PSI)	
Pipe: 1											
S8		39.8	5.6	10.3	18.0	-18.0	6.1	1.101 PL	15.00	PF	1.9
M4		39.8	0.0	12.2	0.0			150 FTG	E3T	PE	-0.0
								0.056 TL	35.00	PV	
Pipe: 2											
S9		39.0	5.6	10.8	18.4	-18.4	6.2	1.101 PL	10.50	PF	1.8
M4		39.8	0.0	12.2	0.0			150 FTG	E3T	PE	-0.4
								0.058 TL	30.50	PV	
Pipe: 3											
S6		39.0	5.6	7.0	14.8	-14.8	5.0	1.101 PL	25.00	PF	2.0
B2		39.8	0.0	8.6	0.0			150 FTG	4ET	PE	-0.4
								0.039 TL	50.00	PV	
Pipe: 4											
S7		39.0	5.6	8.1	15.9	-15.9	5.4	1.101 PL	4.75	PF	0.9
B2		39.8	0.0	8.6	0.0			150 FTG	E2T	PE	-0.4
								0.045 TL	19.75	PV	
Pipe: 6											
B2		39.8	0.0	8.6	0.0	-30.7	10.4	1.101 PL	16.83	PF	6.3
M5		39.8	0.0	14.9	0.0			150 FTG	4ET	PE	0.0
								0.151 TL	41.83	PV	
Pipe: 7											
M5		39.8	0.0	14.9	0.0	-30.7	6.5	1.394 PL	5.25	PF	0.5
32		39.8	0.0	15.4	0.0			150 FTG	T	PE	0.0
								0.048 TL	11.25	PV	
Pipe: 8											
M4		39.8	0.0	12.2	0.0	-36.3	7.6	1.394 PL	5.25	PF	0.7
31		39.8	0.0	12.9	0.0			150 FTG	T	PE	0.0
								0.065 TL	11.25	PV	
Pipe: 9											
31		39.8	0.0	12.9	0.0	-36.3	7.6	1.394 PL	30.25	PF	2.4
01		9.6	0.0	28.4	0.0			150 FTG	T	PE	13.1
								0.065 TL	36.25	PV	
Pipe: 10											
32		39.8	0.0	15.4	0.0	-30.7	6.5	1.394 PL	30.25	PF	1.7
02		9.6	0.0	30.2	0.0			150 FTG	T	PE	13.1
								0.048 TL	36.25	PV	
Pipe: 11											
01		9.6	0.0	28.4	0.0	-36.3	7.6	1.394 PL	28.75	PF	1.9
02		9.6	0.0	30.2	0.0			150 FTG	----	PE	-0.0
								0.065 TL	28.75	PV	
Pipe: 12											
02		9.6	0.0	30.2	0.0	-67.1	14.1	1.394 PL	43.00	PF	19.6
TOR		12.0	0.0	48.8	0.0			150 FTG	8ET	PE	-1.0
								0.202 TL	97.00	PV	
Pipe: 13											
TOR		12.0	0.0	48.8	0.0	-67.1	14.1	1.394 PL	5.00	PF	1.0
BOR		10.5	0.0	50.5	0.0			150 FTG	----	PE	0.6
								0.202 TL	5.00	PV	
Pipe: 14											
BOR		10.5	0.0	50.5	0.0	-67.1	5.7	2.185 PL	4.00	PF	0.1
BFP1		8.1	0.0	51.7	0.0			120 FTG	----	PE	1.0
								0.034 TL	4.00	PV	

DATE: 10/30/2025SS FILES\BUILDING B\AUX CALCS\B - (4) F3QR56 HSW 7PSI.SDF
 JOB TITLE: (4) F3QR HSW 7PSI

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	DIA (IN)	LENGTH	PRESS.
NODES	(FT)	(K)	(PSI)	(GPM)	VEL (FPS)	HW (C)	FL/FT	(FT)	SUM.
									(PSI)
Pipe: 15									
BFP2	8.1	0.0	58.7	0.0					
BFP1	8.1	0.0	51.7	0.0					
FIXED PRESSURE LOSS DEVICE									
						7.0 psi,		67.1 gpm	
Pipe: 16									
BFP2	8.1	0.0	58.7	0.0	-67.1	4.100	PL	60.00	PF 0.1
UG1	0.0	0.0	62.3	0.0	1.6	140	FTG	2ET2G	PE 3.5
						0.001	TL	109.00	PV
Pipe: 16A									
UG1	0.0	0.0	62.3	0.0	-67.1	8.270	PL	390.00	PF 0.0
UG2	0.0	0.0	62.3	0.0	0.4	140	FTG	TBG	PE 0.0
						0.000	TL	463.00	PV
Pipe: 16B									
UG2	0.0	0.0	62.3	0.0	-67.1	12.340	PL	920.00	PF 0.0
UG3	-28.6	0.0	74.7	0.0	0.2	140	FTG	F	PE 12.4
						0.000	TL	939.00	PV
Pipe: 17									
UG3	-28.6	0.0	74.7	0.0	-67.0	6.160	PL	15.00	PF 0.0
SOURCE	-28.6	SRCE	74.7	(N/A)	0.7	140	FTG	TG	PE 0.0
						0.000	TL	59.00	PV

NOTES (HASS):

- Calculations were performed by the HASS 2023 D computer program in accordance with NFPA (2020) under license no. 64621553 granted by HRS Systems, Inc.
 208 Southside Square
 Petersburg, TN 37144
 (931) 659-9760
- The system has been calculated to provide an average imbalance at each node of 0.004 gpm and a maximum imbalance at any node of 0.080 gpm.
- Total pressure at each node is used in balancing the system. Maximum water velocity is 14.1 ft/sec at pipe 12.
- Items listed in bold print on the cover sheet are automatically transferred from the calculation report.
- Available pressure at source node SOURCE under full flow conditions is 94.95 psi with a flow of 83.93 gpm.

DATE: 10/30/2025SS FILES\BUILDING B\AUX CALCS\B - (4) F3QR56 HSW 7PSI.SDF

JOB TITLE: (4) F3QR HSW 7PSI

(6) PIPE FITTINGS TABLE

User Pipe Table Name: SMITH

PAGE: D MATERIAL: DI HWC: 140

Diameter (in)	Equivalent Fitting Lengths in Feet					
	E	T	F	C	B	G
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv
4.100	8.00	27.00	6.00	30.00	20.00	3.00
6.160	12.00	40.00	10.00	43.00	16.00	4.00
8.270	18.00	47.00	12.00	60.00	20.00	6.00
12.340	24.00	80.00	19.00	87.00	34.00	8.00

PAGE: P MATERIAL: CPVC HWC: 150

Diameter (in)	Equivalent Fitting Lengths in Feet						
	E	T	F	R	C	G	B
	Ell	Tee	45	teeRun	Coup	Gva	Bfy
1.101	5.00	5.00	1.00	1.00	1.00	1.00	4.00
1.394	6.00	6.00	2.00	1.00	1.00	1.00	5.00

PAGE: Y MATERIAL: SCH7 HWC: 120


Diameter (in)	Equivalent Fitting Lengths in Feet								
	E	T	F	C	B	G	A	D	X
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv	AlmChk	DPVlv	flex
2.185	4.60	15.20	2.40	14.40	6.20	1.00	12.40	12.40	0.00

DATE: 10/30/2025SS FILES\BUILDING B\AUX CALCS\B - (4) F3QR56 HSW 7PSI.SDF

JOB TITLE: (4) F3QR HSW 7PSI

WATER SUPPLY ANALYSIS


Static: 95.00 psi Resid: 90.00 psi Flow: 1055.0 gpm



DATE: 10/30/2025SS FILES\BUILDING B\AUX CALCS\B - (4) F3QR56 HSW 7PSI.SDF

JOB TITLE: (4) F3QR HSW 7PSI

WATER SUPPLY CURVE



SMITH FIRE SYSTEMS, INC.
JOB NO. TC25207
BRADLEY HEIGHTS: BUILDING B

SYSTEM # 1

L3 (1) HEAD COMPARTMENT

AUXILIARY HYDRAULIC CALCULATION

DENSITY: 0.05 GPM OVER 1 HEADS

SYSTEM DEMAND AT BASE OF RISER

20 GPM AT 36.9 PSI

DATE: 10/30/2025\FILES\BUILDING B\AUX CALCS\B - (1) 20X20 RES49 16.7PSI.SDF

JOB TITLE: B - (1) 20x20 RES49 16.7PSI

WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (PSI)	RESID. PRESS. (PSI)	FLOW @ (GPM)	AVAIL. PRESS. (PSI)	TOTAL @ DEMAND (GPM)	REQ'D PRESS. (PSI)
SOURCE	95.0	90.0	1055.0	95.0	20.0	60.8

Available pressure is 34.2 psi (36%) greater than required pressure.

AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	20.0 GPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	0.0 GPM
OTHER HOSE STREAM ALLOWANCES	0.0 GPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	20.0 GPM

NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)
S1	39.3	K= 4.90	16.7	20.0
M1	39.8	- - - -	19.7	- - -
31	39.8	- - - -	20.8	- - -
01	9.6	- - - -	34.6	- - -
TOR	12.0	- - - -	36.2	- - -
BFP1	8.1	- - - -	37.9	- - -
BFP2	8.1	- - - -	44.9	- - -
BOR	10.5	- - - -	36.9	- - -
UG1	0.0	- - - -	48.4	- - -
UG2	0.0	- - - -	48.5	- - -
UG3	-28.6	- - - -	60.8	- - -
SOURCE	-28.6	SOURCE	60.8	20.0

DATE: 10/30/2025 ILES\BUILDING B\AUX CALCS\B - (1) 20X20 RES49 16.7PSI.SDF

JOB TITLE: B - (1) 20x20 RES49 16.7PSI

PIPE DATA

PIPE TAG	END	ELEV.	NOZ.	PT	DISC.	Q (GPM)	VEL (FPS)	DIA (IN)	LENGTH	PRESS.
NODES	(FT)	(K)	(PSI)	(GPM)				HW (C)	(FT)	SUM.
								FL/FT		(PSI)
Pipe: 1										
S1	39.3	4.9	16.7	20.0		-20.0	6.7	1.101 PL	17.25	PF 3.2
M1	39.8	0.0	19.7	0.0				150 FTG	5ET	PE -0.2
								0.068 TL	47.25	PV
Pipe: 2										
M1	39.8	0.0	19.7	0.0		-20.0	4.2	1.394 PL	20.50	PF 1.1
31	39.8	0.0	20.8	0.0				150 FTG	4ET	PE 0.0
								0.022 TL	50.50	PV
Pipe: 3										
31	39.8	0.0	20.8	0.0		-20.0	4.2	1.394 PL	30.25	PF 0.7
01	9.6	0.0	34.6	0.0				150 FTG	----	PE 13.1
								0.022 TL	30.25	PV
Pipe: 4										
01	9.6	0.0	34.6	0.0		-20.0	4.2	1.394 PL	71.75	PF 2.7
TOR	12.0	0.0	36.2	0.0				150 FTG	8ET	PE -1.0
								0.022 TL	125.75	PV
Pipe: 5										
TOR	12.0	0.0	36.2	0.0		-20.0	1.7	2.185 PL	1.50	PF 0.0
BOR	10.5	0.0	36.9	0.0				150 FTG	----	PE 0.6
								0.002 TL	1.50	PV
Pipe: 6										
BOR	10.5	0.0	36.9	0.0		-20.0	1.7	2.185 PL	2.42	PF 0.0
BFP1	8.1	0.0	37.9	0.0				120 FTG	----	PE 1.0
								0.004 TL	2.42	PV
Pipe: 7										
BFP2	8.1	0.0	44.9	0.0		FIXED PRESSURE LOSS DEVICE				
BFP1	8.1	0.0	37.9	0.0		7.0 psi, 20.0 gpm				
Pipe: 8										
BFP2	8.1	0.0	44.9	0.0		-20.0	0.5	4.100 PL	60.00	PF 0.0
UG1	0.0	0.0	48.4	0.0				140 FTG	2ET2G	PE 3.5
								0.000 TL	109.00	PV
Pipe: 9										
UG1	0.0	0.0	48.4	0.0		-20.0	0.1	8.270 PL	390.00	PF 0.0
UG2	0.0	0.0	48.5	0.0				140 FTG	TBG	PE 0.0
								0.000 TL	463.00	PV
Pipe: 10										
UG2	0.0	0.0	48.5	0.0		-20.0	0.1	12.340 PL	920.00	PF 0.0
UG3	-28.6	0.0	60.8	0.0				140 FTG	F	PE 12.4
								0.000 TL	939.00	PV
Pipe: 11										
UG3	-28.6	0.0	60.8	0.0		-20.0	0.2	6.160 PL	15.00	PF 0.0
SOURCE	-28.6	SRCE	60.8	(N/A)				140 FTG	TG	PE 0.0
								0.000 TL	59.00	PV

DATE: 10/30/2025 FILES\BUILDING B\AUX CALCS\B - (1) 20X20 RES49 16.7PSI.SDF
 JOB TITLE: B - (1) 20x20 RES49 16.7PSI

NOTES (HASS):

- (1) Calculations were performed by the HASS 2023 D computer program in accordance with NFPA (2020) under license no. 64621553 granted by
 HRS Systems, Inc.
 208 Southside Square
 Petersburg, TN 37144
 (931) 659-9760
- (2) The system has been calculated to provide an average imbalance at each node of 0.007 gpm and a maximum imbalance at any node of 0.072 gpm.
- (3) Total pressure at each node is used in balancing the system. Maximum water velocity is 6.7 ft/sec at pipe 1.
- (4) Items listed in bold print on the cover sheet
 are automatically transferred from the calculation report.
- (5) Available pressure at source node SOURCE under full flow conditions is 94.99 psi with a flow of 31.30 gpm.

(6) PIPE FITTINGS TABLE

User Pipe Table Name: SMITH

PAGE: D	MATERIAL: DI		HWC: 140			
Diameter	Equivalent Fitting Lengths in Feet					
(in)	E	T	F	C	B	G
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv
4.100	8.00	27.00	6.00	30.00	20.00	3.00
6.160	12.00	40.00	10.00	43.00	16.00	4.00
8.270	18.00	47.00	12.00	60.00	20.00	6.00
12.340	24.00	80.00	19.00	87.00	34.00	8.00

PAGE: P	MATERIAL: CPVC		HWC: 150				
Diameter	Equivalent Fitting Lengths in Feet						
(in)	E	T	F	R	C	G	B
	Ell	Tee	45	teeRun	Coup	Gva	Bfy
1.101	5.00	5.00	1.00	1.00	1.00	1.00	4.00
1.394	6.00	6.00	2.00	1.00	1.00	1.00	5.00


PAGE: Y	MATERIAL: SCH7		HWC: 120						
Diameter	Equivalent Fitting Lengths in Feet								
(in)	E	T	F	C	B	G	A	D	X
	Ell	Tee	45	ChkVlv	BfyVlv	GatVlv	AlmChk	DPVlv	flex
2.185	4.60	15.20	2.40	14.40	6.20	1.00	12.40	12.40	0.00

DATE: 10/30/2025 ILES\BUILDING B\AUX CALCS\B - (1) 20X20 RES49 16.7PSI.SDF

JOB TITLE: B - (1) 20x20 RES49 16.7PSI

WATER SUPPLY ANALYSIS

Static: 95.00 psi Resid: 90.00 psi Flow: 1055.0 gpm



DATE: 10/30/2025 ILES\BUILDING B\AUX CALCS\B - (1) 20X20 RES49 16.7PSI.SDF

JOB TITLE: B - (1) 20x20 RES49 16.7PSI

WATER SUPPLY CURVE

