



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Date Issued 10 Dec 2025
Permit Number PRFS20251595
Contractor's Name SMITH FIRE SYSTEMS

INSPECTIONS REQUIRED

Fire Sprinkler Final Inspection - Fire Sprinkler Final Inspection

Hydrostatic Test 200Lbs 2Hrs - Hydrostatic Test 200Lbs 2Hrs

Fire Sprinkler Dry System Trip Test - Fire Sprinkler Dry System Trip Test

Fire Sprinkler Cover Inspection - Fire Sprinkler Cover Inspection