



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Dec 10, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCNC20251084

**Property Address:** 731 SHAW RD PUYALLUP, WA. 98372

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** covered trash enclosure shared by the commercial lot 1 and lot 2, - 731 SHAW RD

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** remove standing water before concrete pour. Reroute electrical lines out of running along footings.

**Corrections:**

Sincerely,

James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590