

December 16, 2025

To: City of Puyallup – Development and Permitting
333 S Meridian, 2nd Floor
Puyallup, WA 98371

Att: Planning and Development

Re: Kaiser Permanente Medical Center TI

To Whom it may concern:

The modifications shown on the sprinkler shop drawings for this tenant improvement will not change the hydraulic demand of the existing sprinkler system. The hazard classification is remaining unchanged. This project consists of relocating two fire sprinklers only to accommodate the new tenant improvement changes. The existing supply, riser, backflow preventer, mains and branch lines are remaining as existing.

If you have any questions please feel free to reach out, thanks!

Sincerely,
PATRIOT FIRE PROTECTION, INC.

Davin Christenson
Project Manager
253-284-3401

