



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRDK20251632

December 29, 2025

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections. Below, please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must address all comments and upload a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please note: If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at the bottom of the page.
- 3 If any resubmittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Engineering Review	Yianni Charitou	(253)435-3612	YCharitou@PuyallupWA.gov
<p>- Provide a letter from the project's Engineer-of-Record that the imposed dead and live loads of the proposed playground will not damage the RTank below the playground or, in any way, alter the capacity or function of the RTank. [SITE PLAN ; 2025\PRDK20251632\Site Plan_ETC_Playground Equipment.pdf; pg. 1]</p> <p>- Provide an elevation detail or profile of the proposed playground footings in relation to the existing RTank and backfill. The "Example of Footer" found in the submitted playground equipment specification does not adequately identify the separation between the footers and the distance from the minimum 12" of free draining backfill stone above the tank. [SITE PLAN ; 2025\PRDK20251632\Site Plan_ETC_Playground Equipment.pdf; pg. 1]</p>			
Engineering Storm Review	Mark Higginson	(253)841-5559	MHigginson@PuyallupWA.gov
<p>- Provide a letter from the project's Engineer-of-Record addressing the following:</p> <ol style="list-style-type: none"> 1) The original stormwater design indicated the area of the proposed playground to be non-pollution generation lawn surface. Is there a water quality concern with the use of the 10in thick rubber mulch surfacing? Is the material inert? Provide supporting documentation if there is no water quality concern. 2) There is no impact to the flow control facilities due to the addition of the playground equipment. 3) There is no impact to the RTank below the proposed playground equipment considering the associated footing depth required for the equipment. [SITE PLAN ; 2025\PRDK20251632\Site Plan_ETC_Playground Equipment.pdf; pg. 1] 			

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
--------------------	-----------	------------	------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1
permitcenter@puyallupwa.gov