



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 31, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRMU20230881

Property Address: 707 39TH AVE SE, Unit: D, PUYALLUP, WA 98374;

Contractor: Anthony Mizin 315 fifth Ave S. Suite 600 Seattle, WA 98104 WALSH CONSTRUCTION CO. 315 FIFTH AVE S, SUITE 600 SEATTLE, WA 98104- (206) 547-4008

To construct: As part of the Phase 2 development of Wesley Bradley Park, - Group R2 w/ 3 stories Type VA over Type 1A concrete garage. This project has 67 dwelling units. - WESLEY HOMES BRADLEY PARK PH 2 - BROWNSTONE * REVISION (1) - 6/24/2025 - ENERGY CODE CALS, EV CAR LOCATION AND GARAGE AND DAS SYSTEM LOCATION.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Okay to insulate

3rd floor elevator shaft finish nailing A-35s

1st floor install anchor bolt front left side

Corrections:

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590