



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 05, 2026

Inspection Result: NOT READY

Permit Number: PRCNC20241917

Property Address:

Contractor: E M PRECISION LLC 1407 VALENTINE AVE SE, STE 105 PACIFIC, WA 98047 (253) 268-0742

To construct: Ground up construction of a McDonald's with a Drive Through. - MCDONALD'S - EAST TOWN CROSSING - 731 SHAW RD

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Insulate water lines at water heaters.
2. Provide RPBA at commercial dishwasher.
3. Provide hammer arrestor at ice machine.

Corrections:

- 1 1. Insulate water lines at water heaters.
2. Provide RPBA at commercial dishwasher.
3. Provide hammer arrestor at ice machine.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590