



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 05, 2026                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20241846

**Property Address:** 731 SHAW RD, PUYALLUP, WA 98372

**Contractor:** EM Precision, LLC 1407 Valentine Ave SE, Suite 105 Pacific, WA 98047--  
2104

**To construct:** Ground up commercial fast food restaurant with a drive through. -  
MCDONALD'S - EAST TOWN CROSSING - 731 SHAW RD

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 12/30- working on building

12/31- working on building

1/2/26 - working on building

1/5/26 - Contractor is working on corrections list. Begin official punchlist.

**Corrections:**

1. Remove storm plug and install in upper CB. (COMPLETED)
2. Install concrete collar around type 1 CB in planter. NE corner of site.
3. Install 4" cap and adaptor in storm c/o. East side of building, south of entrance. (COMPLETED)
4. Paint hydrants. Rust-Oleum Safety Yellow (2 coats) (COMPLETED)
5. Install concrete collars around all GV's in planter areas.
6. Install 90deg. bend, 30deg. storz adaptor, and Knox cap on FDC. Central Pierce Fire.
7. Prime & paint FDC. Clean prior to prime, prime w/ self etching metal primer, and paint with Marathon Safety Red. (COMPLETED)
8. Install signage on FDC.
9. Paint PIV. Marathon Safety Red. (COMPLETED)
10. Verify fire vault pump operation. (COMPLETED)
11. Add 1/2" diameter holes for lid channel drainage. (COMPLETED)
12. Clean lid channel. (COMPLETED)
13. Repair sewer sag at tie in area. (COMPLETED)



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

14. Need MXU installed on fire vault meter.
15. Grout both pipes where water intrusion is occurring.

Sincerely,

Jason Little  
Development Engineering Inspector  
[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)  
(253) 244-0387