



City of Puyallup
Building Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 06, 2026

Inspection Result: NOT READY

Permit Number: PRCTI20250324

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 773-3360

To construct: Commercial tenant improvement to existing 50,767 sf space - COP ~ PUBLIC SAFETY BUILDING * REVISION (1) - 8/21/2025 - GENERATOR DEFERRED SUBMITTAL * REVISION (2) - 10/30/2025 - EXTERIOR CANOPY CONNECTIONS

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: talked with contractor about bracing of duct work as per plans.

Corrections:

Sincerely,

A handwritten signature in black ink, appearing to read "Shannon King".

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684