



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 08, 2026

Inspection Result: **PARTIAL PASS**

Permit Number: PRMU20230881

Property Address: 707 39TH AVE SE, Unit: D, PUYALLUP, WA 98374;

Contractor: Anthony Mizin 315 fifth Ave S. Suite 600 Seattle, WA 98104 WALSH CONSTRUCTION CO. 315 FIFTH AVE S, SUITE 600 SEATTLE, WA 98104- (206) 547-4008

To construct: As part of the Phase 2 development of Wesley Bradley Park, - Group R2 w/ 3 stories Type VA over Type 1A concrete garage. This project has 67 dwelling units. - WESLEY HOMES BRADLEY PARK PH 2 - BROWNSTONE * REVISION (1) - 6/24/2025 - ENERGY CODE CALS, EV CAR LOCATION AND GARAGE AND DAS SYSTEM LOCATION.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: L2 framing north. Okay to insulate

1. Several missed fire caulking at plumbing penetrations.
2. Fire tape shower drain sheetrock where cut, fire caulk around perimeter of sheetrock at shower drains.
3. A few dryer nail plates missing.
4. Several hold downs still needing fire caulk removal.
5. Provide strapping at bedroom wall unit 2025.

Corrections:

Sincerely,

James LaVergne
JLaVergne@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 841-5590