



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 08, 2026

Inspection Result: PARTIAL PASS

Permit Number: PRCTI20250558

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: SELLEN CONSTRUCTION CO INC PO BOX 9970 SEATTLE, WA 98109-9970 ABBOTT CONSTRUCTION 3408 1ST AVENUE SOUTH SEATTLE, WA 98134

To construct: Phase 0 will create new storage capacity and access points for hospital staff prior to the full buildout of the expanded Kitchen. MULTICARE GOOD SAMARITAN HOSPITAL KITCHEN PHASE 0

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Phase 0 grid ceiling complete.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684