



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 13, 2026

Inspection Result: PARTIAL PASS

Permit Number: PRCCP20240808

Property Address: 911 SHAW RD, PUYALLUP, WA 98372; 901 SHAW RD, PUYALLUP, WA 98372; 813 SHAW RD, PUYALLUP, WA 98372;

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Phase 2 site development of East Town Crossing including grading, storm drainage, parking, and utilities per plans. - 731 SHAW RD

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1/9 - McKee cleaned the side sewers and sewer main for building (old E new B). They are working on the ladder install for the fire vault at the commercial building.

1/12 - McKee is installing the pool deck drain and tying it install the roof drains.

1/13 - McKee finished the storm stub for the deck drains around the pool. They are grading around the pool. Landscape contractor is working on the landscape around building B.

Corrections:

- 1 Corrections for building "B" final.
 1. Clean CB socks after entire parking lot has been cleaned.
 2. Finish landscape around entire building.
 3. Clean rocks from around hydrant and fire line gate valve nut.
 4. Repair fire vault pump and show operation.
 5. Clean PVC and concrete from sewer channel on SSMH1. NW corner of building.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387