



City of Puyallup  
**Building Division**  
333 S. Meridian, Puyallup, WA 98371  
(253) 864-4165  
[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jan 16, 2026

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20250324

**Property Address:** 1015 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 773-3360

**To construct:** Commercial tenant improvement to existing 50,767 sf space - COP ~ PUBLIC SAFETY BUILDING \* REVISION (1) - 8/21/2025 - GENERATOR DEFERRED SUBMITTAL \* REVISION (2) - 10/30/2025 - EXTERIOR CANOPY CONNECTIONS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; inspection of shaft liner at east, west, and north wall in at room A1132 shaft.

**Corrections:**

Sincerely,

A handwritten signature in black ink that reads "Shannon King". The signature is fluid and cursive, with "Shannon" on the left and "King" on the right.

Shannon King  
Building Inspector 2  
[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)  
(253) 840-6684