



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 21, 2026

Inspection Result: NOT READY

Permit Number: PRCTI20250558

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: SELLEN CONSTRUCTION CO INC PO BOX 9970 SEATTLE, WA 98109-9970 ABBOTT CONSTRUCTION 3408 1ST AVENUE SOUTH SEATTLE, WA 98134

To construct: Phase 0 will create new storage capacity and access points for hospital staff prior to the full buildout of the expanded Kitchen. MULTICARE GOOD SAMARITAN HOSPITAL KITCHEN PHASE 0

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Provide DOH tab report.
2. Finish end of hallway 1 hour wall.

Corrections:

1. Provide DOH tab report.
2. Finish end of hallway 1 hour wall.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590