



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 26, 2026

Inspection Result: **PASSED W/
CONDITIONS**

Permit Number: PRCTI20250324

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 773-3360

To construct: Commercial tenant improvement to existing 50,767 sf space - COP ~ PUBLIC SAFETY BUILDING * REVISION (1) - 8/21/2025 - GENERATOR DEFERRED SUBMITTAL * REVISION (2) - 10/30/2025 - EXTERIOR CANOPY CONNECTIONS

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: A side of project. Leave several ceiling tiles out so spot checks can be done.

1. Provide positive attachment of burke clips to studs or CG angle brackets.
2. Provide wire ties to all speaker and lights in CG.
3. Missing duct seal on a couple joints.
4. Provide caddy clips on all flat return diffusers.

Corrections:

- 2 Leave several ceiling tiles out so spot checks can be done.
 1. Provide positive attachment of burke clips to studs or CG angle brackets.
 2. Provide wire ties to all speaker and lights in CG.
 3. Missing duct seal on a couple joints.
 4. Provide caddy clips on all flat return diffusers.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov
(253) 841-5590