



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 30, 2026

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20250548

**Property Address:** 401 15TH AVE SE, PUYALLUP, WA 98372;

**Contractor:** ABBOTT CONSTRUCTION 3408 1ST AVENUE SOUTH SEATTLE, WA 98134

**To construct:** This Tenant Improvement on Level 1 of the Good Samaritan Hospital Campus will expand the existing Nutrition Department in order to support the future Patient Care Tower expansion (WA DOH Certificate of Need 1980). Project will be reviewed by WA DOH under CRS# 61682265. Due to hospital requirements for continuous operation, this project is planned for construction in multiple phases in order to maintain Food Service and Dining operations for the hospital. Phase 1 will create new Storage, Ware wash, Cooking, and Office spaces to serve multiple departments. Scope also includes new infrastructure needed to support this added capacity. - MULTICARE GOOD SAMARITAN HOSPITAL KITCHEN PHASE 1

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. Provide positive attachment of grid wire to structure or studs.  
2. Positive attachment of diffusers to grid main runs.  
3. Attache burke clips to wall under duct runs.  
4. Seal penetrations at walls above grid ceiling.  
5. Add missing wires at required locations.

**Corrections:**

- 1 1. Provide positive attachment of grid wire to structure or studs.
2. Positive attachment of diffusers to grid main runs.
3. Attache burke clips to wall under duct runs.
4. Seal penetrations at walls above grid ceiling.



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

5. Add missing wires at required locations.

Sincerely,



James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590