



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 11, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20240407

Property Address: 3002 E PIONEER BLDG C, PUYALLUP WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING A 3-story apartment building - EAST TOWN CROSSING -
REASSIGNED AS 3002 E PIONEER - BLDG C

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Okay to sheetrock

1. Unit 104-bathroom electrical runs under beam interfering with hard lid 1 hour rating. Do not sheetrock this spot until fix is performed.

Corrections:

1 Okay to sheetrock

1. Unit 104-bathroom electrical runs under beam interfering with hard lid 1 hour rating. Do not sheetrock this spot until fix is performed.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590