



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 13, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRFUP20251396

Property Address: 3002 E PIONEER, PUYALLUP WA 98372

Contractor: INFRA SOURCE SERVICES LLC 14103 STEWART RD PUYALLUP, WA 98371

To construct: PERMIT EXT TO 08/09/2026 107063979- WORK IN ROW TO INSTALL GAS MAIN EXTENSION. ONE 2X4 SIDEWALK CUT. THREE 2X4 GRASS CUTS. - 727 SHAW RD/3002 E PIONEER

On this day we have inspected your construction for **Close All Restoration Complete Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: AA Asphaltting set up an outside lane closure east on Pioneer. Panels were sawcut and removed. Pervious concrete was poured and rolled, and the new panels were covered with visqueen. Note: Cover is to remain for a minimum 7 days.

Correction: Infrasource needs to add topsoil, seed and straw at the back of walk where trenching occurred behind the retaining wall. The surface has settled.

Corrections:

Sincerely,

Cheryl Trimble

Engineer Technician III

CTrimble@PuyallupWA.gov

(253) 290-9834



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org