



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Feb 17, 2026

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRMU20240407

**Property Address:** 3002 E PIONEER BLDG C, PUYALLUP WA 98372

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** BUILDING A 3-story apartment building - EAST TOWN CROSSING -  
REASSIGNED AS 3002 E PIONEER - BLDG C

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. Over driven screws throughout units. Drop back add screws throughout not as deep.  
2. Missing duct work in unit 104 bathroom.

**Corrections:**

1. Over driven screws throughout units. Drop back add screws throughout not as deep.
2. Missing duct work in unit 104 bathroom.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)



James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590