



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 23, 2026

Inspection Result: NOT READY

Permit Number: PRMU20240402

Property Address:

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: ISSUED AS BUILDING E 3-story apartment building - EAST TOWN
CROSSING - REASSIGNED AS 3002 E PIONEER - BLDG B

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Previous corrections complete.
2. Unit 104 ADA toilet flange moved toilet not set.
3. West side ADA unit toilet @19.5 as well

Corrections:

1. Previous corrections complete.
2. Unit 104 ADA toilet flange moved toilet not set.
3. West side ADA unit toilet @19.5 as well

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org



James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590