



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 26, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCNC20250094

Property Address: 727 SHAW RD, PUYALLUP, WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: Construction of a 5,000 sq ft, 1-story commercial, 'shell" building. - EAST TOWN CROSSING, LOT 1 COMMERCIAL BLDG W/2 FUTURE TENANTS -- 727 SHAW RD

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Inspected items for building final.

- Fire vault, FDC, & PIV are good. Sewer GI needs baffle tee straightened and seated, vent cut flush, and bolts installed in lid.

- We have not inspected the two CB's in the parking lot for cleanliness. These were only protected with socks while there were stockpiles near by. Parking lot needs to be cleaned prior to inspecting.

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387