



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 02, 2026 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRFUP20251396

Property Address: 3002 E PIONEER, PUYALLUP WA 98372

Contractor: INFRASOURCE SERVICES LLC 14103 STEWART RD PUYALLUP, WA 98371

To construct: PERMIT EXT TO 08/09/2026 107063979- WORK IN ROW TO INSTALL GAS MAIN EXTENSION. ONE 2X4 SIDEWALK CUT. THREE 2X4 GRASS CUTS. - 727 SHAW RD/3002 E PIONEER

On this day we have inspected your construction for **Closeout All Work Complete (No Restoration) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Soft surface restoration was sufficiently completed.

Note: For hard surface restoration, it was observed that there were no tooled joints connecting the existing pervious panels to the ones that were replaced, as discussed. An email was sent to the restoration contractor, and the panels will need to be monitored in case raveling occurs where the joints are missing.

Corrections:

Sincerely,

Cheryl Trimble

Engineer Technician III

CTrimble@PuyallupWA.gov



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 290-9834