



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Dec 16, 2021                      **Inspection Result:**     **FAILED**

**Permit Number:** B-19-1101

**Property Address:** 3500 S MERIDIAN            ;

**Contractor:** ALEGIS CONSTRUCTION INC 6900 SW ATLANTA ST. BLDG PORTLAND,  
OR 97223

**To construct:** INTERIOR DEMO AND SOME SEISMIC UPGRADES ~ ROUND 1  
ENTERTAINMENT VENUE  
TRAFFIC IMPACT FEES TO BE ASSESSED DURING PENDING TI BUILDING  
PERMIT - BR  
BLDG/MECH

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** INSP FRAME - No Comments

**Corrections:**

- 1 ; complete all firestop at rated wall as per city approved plans as discussed with Tom and complete marking and identification of rated wall as per section 703.7 of I.B.C. prior to reinspection.

Sincerely,

Shannon King  
Building Inspector 2



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684