



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 22, 2021 **Inspection Result:** **FAILED**

Permit Number: B-19-1101

Property Address: 3500 S MERIDIAN ;

Contractor: ALEGIS CONSTRUCTION INC 6900 SW ATLANTA ST. BLDG PORTLAND,
OR 97223

To construct: INTERIOR DEMO AND SOME SEISMIC UPGRADES ~ ROUND 1
ENTERTAINMENT VENUE
TRAFFIC IMPACT FEES TO BE ASSESSED DURING PENDING TI BUILDING
PERMIT - BR
BLDG/MECH

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 ; complete all firestop at rated wall as per city approved plans as discussed with Tom and complete marking and identification of rated wall as per section 703.7 of I.B.C. prior to next inspection. (as noted on frame inspection dated 12/16/2021)

Sincerely,

Shannon King
Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

ShannonK@PuyallupWA.gov

(253) 840-6684