



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # E-21-0440

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Engineering Civil Review (Reviewed By: Mark Higginson, (253)841-5559, MHigginson@PuyallupWA.gov)

- ◆ 3-in FM[Pump Calcs]
- ◆ Provide reference for friction loss equation [Pump Calcs]
- ◆ Provide reference (exhibit, appendix, etc) for existing pump system [Pump Calcs]
- ◆ Locate sewer and GI 10-ft min from Bldg[Plans; Sht S2]
- ◆ Size does not agree w/ calcs. See review comments on GI calcs too.[Plans; Sht S2]
- ◆ Per prior comment, verify...ROW = 20+16.5 = 36.5?[Plans; Sht S2]
- ◆ Provide acceptance from Williams Gas for new sewer crossing the gas easement[Plans; Sht S2]
- ◆ Provide acknowledgement from Williams Gas for sewer alignment through their gas easement.
- ◆ Submit Engineering Cost Estimate Worksheet (City form) for review prior to permit issuance.

To resubmit, you must address all comments and complete the [resubmittal form](#). Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov