



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 10, 2022

**Inspection Result:** **FAILED**

**Permit Number:** B-21-0704

**Property Address:** 401 VALLEY AVE NE ;

**Contractor:** MERIDIAN POINTE APARTMENTS LLC PO BOX 66826 SEATTLE, WA  
98166--0826

**To construct:** INTERIOR UNIT BLDG RENOVATION ~ MERIDIAN POINTE  
APARTMENTS/BLDG E  
UNITS 104/204/304

BLDG ONLY

On this day we have inspected your construction for **Carbon Monoxide Detectors Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** INSP CARBON MONOXIDE DETECTORS - No Comments

**Corrections:**

- 1 1 ; no 110 power at smoke/carbon alarm in hall at unit 104 at time of building final inspection.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 840-6684