

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Jan 10, 2022	Inspection Result:	FAILED
Permit Number: Property Address:	B-21-0704 401 VALLEY AVE NE	;	
Contractor:	MERIDIAN POINTE APAF 981660826	RTMENTS LLC PO BOX 66	5826 SEATTLE, WA
To construct:	INTERIOR UNIT BLDG RI APARTMENTS/BLDG E UNITS 104/204/304	enovation ~ Meridia	N POINTE
	BLDG ONLY		

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP COMMENT - No Comments

Corrections:

- 1 1; provide fire final inspection approval prior to building final inspection.
 - 2 ; provide refrigerator/freezer per ICC A117.1 section 804.5.6 in unit 104.(accessible unit)
 - 3 ; City approved plans not on-site at time of inspection.

Sincerely,

non King

Shannon King Building Inspector 2



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

ShannonK@PuyallupWA.gov (253) 840-6684