



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
F-21-0128

FIRE ALARMS

Puyallup, WA

Job Address	Address: 3500 S MERIDIAN Parcel # 602101005160215900706021590090	ISSUED January 11, 2022
Owner	CAFARO NORTHWEST PARTNERSHIP 3500 S MERIDIAN ANNANDALE, NJ 08801	
Applicant	Red Hawk Fire Protection 801 Valley Avenue NW, Suite D, Suite D Puyallup, WA 98371 (253) 840-9900 Insp-permit@redhawkfp.com	
Contractor	RED HAWK FIRE PROTECTION LLC 801 VALLEY AVE NW PUYALLUP, WA 98371-3230 WA L&I #:	
Description of Work	ADD SMOKE DETECTOR TO CHANGING ROOM ~ LUNCH BOX	
Permit Types	Fire Alarms	
Expiration Date:	July 10, 2022	

Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
1	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration	\$0.00	\$0.00
Total Value of Work:				\$0.00

Standard Conditions:

- 1- APPOINTMENT REQUIRED FOR ALL INSPECTIONS
- 2- PROVIDE PLANS AND PERMIT ON SITE FOR INSPECTION.
- 3- COMPLETE LABOR AND INDUSTRIES INSPECTIONS PRIOR TO REQUESTING CITY INSPECTION.
- 4- A REMOTE ANNUNCIATOR LOCATED ON THE EXTERIOR OF THE MAIN ENTRANCE IN A WEATHER PROOF HOUSING REQUIRED.
- 5- EXTERIOR FIRE BELL REQUIRED OUTSIDE FIRE SPRINKLER ROOM.
- 6- DEVICE MAPS REQUIRED AT THE ANNUNCIATOR AND FIRE ALARM PANEL PRIOR TO CALLING IN FINAL. THE ANNUNCIATOR MAP WILL NEED TO BE WEATHER PROOF.
- 7- TOTAL COVERAGE IS REQUIRED; SUBJECT TO FIELD INSPECTION. COMPLY WITH NFPA 72, 2013
- 8- FIRE ALARM SYSTEM SHALL BE PLACARDED PER NFPA 72. THE UL CERTIFICATE SHALL BE POSTED AT TIME OF FINAL INSPECTION. THE SYSTEM WILL NEED TO BE UL CERTIFIED.
- 9- A PRE-TEST SHALL BE CONDUCTED AND A PRINT OUT OF THE LOCATION OF THE DEVICE, POINT NUMBER AND DESCRIPTOR SHALL BE FURNISHED TO THE INSPECTOR AT FINAL.
- 10- FIRE SPRINKLER TAMPER VALVES AND PIV WILL BE REQUIRED TO BE TESTED AT INSPECTION. FIRE SPRINKLER

CONTRACTOR TO BE ONSITE.

11- THE CITY OF PUYALLUP ALLOWS ONE FACP PER BUILDING. THE PANEL WILL NEED TO BE LARGE ENOUGH TO HANDLE MULTIPLE TENTANTS IF APPLICABLE.

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Red Hawk Fire Protection