
10/

DCASEY



CITY OF PUYALLUP. City of Puyallup City of Puyallup Building APPROVED Developmen Engineering APPROVED See permit See permit requirements for additional **JMontgomer** 12/30/2021 01/03/2022 2:28:53 PM 12:04:04 PM

**Engineering approval** 

required for utility

disconnects prior to

building inspection

required.

final. Final inspection

Prior to starting site work, request an erosion and sediment inspection through the CityView portal.

Refer to the City standard details 02.03.02 & 05.02.01 for typical erosion and sedimentation control methods.

The applicant is responsible to demolish the existing private well per Pierce County Health Department Requirements. A decommissioning certificate is required to be filed with Pierce County and a copy shall be provided to the City of Puyallup. If the well is to remain for irrigation purposes a Reduced Pressure Backflow Assembly is required. See the attached City of Puvallup Standard Detail 03.04.02

SEPTIC SYSTEMS SHALL BE ABANDONED PER TACOMA PIERCE COUNTY HEALTH DEPARTMENT REGULATIONS. A

DECOMMISSIONING CERTIFICATE IS REQUIRED TO BE FILED WITH TPCHD AND A COPY SHALL BE PROVIDED TO THE

The applicant is responsible to demolish the existing septic system per Pierce County Health Department requirements. A decommissioning certificate is required to be filed with Pierce County and a copy shall be provided to the City of Puyallup.


APPROVED PLAN CITY OF PUYALLUP PLANNING DIVISION

APPROVED BY: NComstock

DATE: 01/10/2022

CASE NO. PRDE20210053

CONDITIONS: No ground disturbing activities or removal of foundations. To prevent impacts to wetland, demolition must be limited to within 5' of all structures and a high visibility fence must be tree protection detail



8

PARCEL K

APN 042020-1034

PROVIDED APN 042020-1052

APN 042020-1036

PN 042020-5004

PARCEL H

APN 042020-5003

APN

50TH ST. E.

TANDEN TO 49TH ST. E.

SHEET 4

SHEET 5



N 042020-1032

APN 042020-1042

PARCEL C

APN 042020-1027

PARCELS TO BE

PARCEL G

APN 042020-1101

LEFT UNDISTURBED

## Barghausen Consulting Engineers, Inc.

PARCELS TO BE

APN 042020-0111

APN 042020-5013

APN 042020-5010

LEFT UNDISTURBED


18215 72nd Avenue South Kent, W 98032 425.251.6222 barghausen.com For: **VECTOR DEVELOPMENT COMPANY** 

Title: FREEMAN ROAD LOGISTICS **DEMOLITION PLAN** 

Job Number 21585


Sheet

# **APPROVED**




10/7/2021 4:12 P:\21000s\21585\engineering\21585-Demo.dwg

#### **APPROVED**



PM 10/7/2021 P:\21000s\21585\engineering\21585-Demo.dwg



### **APPROVED**

