



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 13, 2022

**Inspection Result:** **FAILED**

**Permit Number:** B-21-0534

**Property Address:** 400 15TH AVE SE, PUYALLUP, WA 98372;

**Contractor:** MCKINSTRY CO. 5005 3RD AVE S SEATTLE, WA 98124

**To construct:** RTU REPLACEMENT

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** INSP FINAL MECHANICAL -provide final balance report

**Corrections:**

- 1 provide final balance report

Sincerely,

Gary Webster

Building Inspector

GWebster@PuyallupWA.gov

(253) 841-5590