



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 13, 2022                      **Inspection Result:**     **PASSED**

**Permit Number:** B-21-0704

**Property Address:** 401 VALLEY AVE NE            ;

**Contractor:** MERIDIAN POINTE APARTMENTS LLC PO BOX 66826 SEATTLE, WA  
98166--0826

**To construct:** INTERIOR UNIT BLDG RENOVATION ~ MERIDIAN POINTE  
APARTMENTS/BLDG E  
UNITS 104/204/304

BLDG ONLY

On this day we have inspected your construction for **Carbon Monoxide Detectors Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; no 110 power at smoke/carbon alarm in hall at unit 104 at time of building final inspection.

Sincerely,

Gary Webster

Building Inspector

GWebster@PuyallupWA.gov

(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)